

ENERGY AUDIT OF ARMY INDUSTRIAL FACILITY (EEAP)  
DETROIT ARSENAL TANK PLANT, BUILDING 4  
WARREN, MICHIGAN

Final Report  
Executive Summary

DEPARTMENT OF THE ARMY  
LOUISVILLE DISTRICT, CORPS OF ENGINEERS  
LOUISVILLE, KENTUCKY

19971021 283

DTIC QUALITY INSPECTED 2

September 27, 1985

Smith, Hinchman & Grylls Associates, Inc.  
455 West Fort Street  
Detroit, Michigan 48226

**DISTRIBUTION STATEMENT A**

Approved for public release  
Distribution Unlimited




DEPARTMENT OF THE ARMY  
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS  
P.O. BOX 9005  
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO  
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.  
Distribution A. Approved for public release.

  
Marie Wakefield,  
Librarian Engineering

## TABLE OF CONTENTS

|   | <u>Page</u> |
|---|-------------|
| <b>1. EXECUTIVE SUMMARY</b>                             |             |
| 1.1 Introduction . . . . .                              | 1           |
| 1.2 Historical Energy Consumption . . . . .             | 3           |
| 1.2.1 Introduction . . . . .                            | 3           |
| 1.2.2 Electrical Consumption . . . . .                  | 3           |
| 1.2.3 Natural Gas Consumption . . . . .                 | 3           |
| 1.2.4 Steam Consumption . . . . .                       | 8           |
| 1.2.5 FY 83 Consumption . . . . .                       | 8           |
| 1.3 Present Energy Consumption . . . . .                | 12          |
| 1.3.1 Introduction . . . . .                            | 12          |
| 1.3.2 Present Electrical Consumption . . . . .          | 12          |
| 1.3.3 Present Natural Gas Consumption . . . . .         | 14          |
| 1.3.4 Present Steam Consumption . . . . .               | 14          |
| 1.3.4 Conclusions . . . . .                             | 18          |
| 1.4 Production Profile . . . . .                        | 23          |
| 1.5 Pending and Prior Projects . . . . .                | 24          |
| 1.5.1 Building Envelope . . . . .                       | 24          |
| 1.5.2 Mechanical Systems . . . . .                      | 25          |
| 1.5.3 Process Systems . . . . .                         | 26          |
| 1.5.4 Electrical Systems . . . . .                      | 26          |
| 1.5.5 Energy Management and Control<br>System . . . . . | 28          |
| 1.5.6 Interior Spaces . . . . .                         | 28          |
| 1.5.7 Energy Production . . . . .                       | 28          |
| 1.6 Energy Conservation Analysis . . . . .              | 29          |
| 1.6.1 Introduction . . . . .                            | 29          |
| 1.6.2 ECO's Investigated . . . . .                      | 30          |
| 1.6.3 ECO's Recommended . . . . .                       | 45          |
| 1.7 Energy and Cost Savings . . . . .                   | 54          |
| 1.7.1 Introduction . . . . .                            | 54          |
| 1.7.2 Electrical Consumption . . . . .                  | 54          |
| 1.7.3 Natural Gas Consumption . . . . .                 | 58          |
| 1.7.4 Coal Consumption . . . . .                        | 58          |
| 1.7.5 Conclusions . . . . .                             | 58          |

## NARRATIVE SUMMARY

|   | <u>Page</u> |
|---|-------------|
| <b>1. EXECUTIVE SUMMARY</b>                             |             |
| 1.1 Introduction . . . . .                              | 1           |
| 1.2 Historical Energy Consumption . . . . .             | 3           |
| 1.2.1 Introduction . . . . .                            | 3           |
| 1.2.2 Electrical Consumption . . . . .                  | 3           |
| 1.2.3 Natural Gas Consumption . . . . .                 | 3           |
| 1.2.4 Steam Consumption . . . . .                       | 3           |
| 1.2.5 FY 83 Consumption . . . . .                       | 10          |
| 1.3 Present Energy Consumption . . . . .                | 12          |
| 1.3.1 Introduction . . . . .                            | 12          |
| 1.3.2 Present Electrical Consumption . . . . .          | 12          |
| 1.3.3 Present Natural Gas Consumption . . . . .         | 14          |
| 1.3.4 Present Steam Consumption . . . . .               | 16          |
| 1.3.5 Conclusions . . . . .                             | 16          |
| 1.4 Production Profile . . . . .                        | 22          |
| 1.5 Pending and Prior Projects . . . . .                | 23          |
| 1.5.1 Building Envelope . . . . .                       | 24          |
| 1.5.2 Mechanical Systems . . . . .                      | 24          |
| 1.5.3 Process Systems . . . . .                         | 24          |
| 1.5.4 Electrical Systems . . . . .                      | 25          |
| 1.5.5 Energy Management and Control<br>System . . . . . | 25          |
| 1.5.6 Interior Spaces . . . . .                         | 25          |
| 1.5.7 Energy Production . . . . .                       | 26          |
| 1.6 Energy Conservation Analysis . . . . .              | 27          |
| 1.6.1 Introduction . . . . .                            | 27          |
| 1.6.2 ECO's Investigated . . . . .                      | 28          |
| 1.6.3 ECO's Recommended . . . . .                       | 40          |
| 1.7 Energy and Cost Savings . . . . .                   | 49          |
| 1.7.1 Introduction . . . . .                            | 49          |
| 1.7.2 Electrical Consumption . . . . .                  | 49          |
| 1.7.3 Natural Gas Consumption . . . . .                 | 49          |
| 1.7.4 Coal Consumption . . . . .                        | 56          |
| 1.7.5 Conclusions . . . . .                             | 56          |

## NARRATIVE SUMMARY (cont'd.)

|  | <u>Page</u> |
|--|-------------|
| <b>2. METHODS AND APPROACH</b>   |             |
| 2.1 General . . . . .  | 64          |
| 2.2 Basic Information . . . . .  | 64          |
| 2.2.1 Information from the Louisville<br>District Corps of Engineers . .                                   | 64          |
| 2.2.2 Information from TACOM (Tank<br>Arsenal Command) . . . . .   | 65          |
| 2.2.3 Information from Facility Operating<br>Contractor (General Dynamics) .                               | 65          |
| 2.2.4 Information Obtained by Smith,<br>Hinchman & Grylls Associates,<br>Inc. . . . .                      | 66          |
| 2.3 Field Survey and Interviews with Operating<br>Personnel . . . . .                                      | 66          |
| 2.4 Review of Drawings and Specifications . . .  | 66          |
| 2.5 Preliminary Identification and Evaluation<br>of Energy Conservation Opportunities<br>(ECO's) . . . . . | 66          |
| 2.6 Review of Previous ECO's Not Implemented .   | 66          |
| 2.6.1 Project B-1 - Modification to the<br>Electrical and Steam Distribution<br>Systems . . . . .          | 67          |
| 2.6.2 Project F-2 - ECO's for GOCO<br>Buildings 4, 5 and 59 . . . . .                                      | 67          |
| 2.6.3 Project F-5 - Building 4, Surface<br>Treatment Tanks . . . . .                                       | 67          |
| 2.7 Categorize Recommended ECO's . . . . .   | 67          |
| 2.7.1 Proposed ECAM Projects . . . . .   | 68          |
| 2.8 Concurrence with the Corps of Engineers . .  | 69          |
| 2.9 Documentation of Fundable Projects . . . .   | 69          |
| 2.9.1 ECAM Projects . . . . .  | 69          |
| 2.9.2 Non-ECAM Projects . . . . .  | 70          |
| 2.9.3 Low Cost/No Cost . . . . .   | 70          |
| 2.9.4 Non-feasible ECO's . . . . .   | 70          |

## NARRATIVE SUMMARY (cont'd.)

Page

### 3. IDENTIFICATION OF ECO's

|       |  |     |
|-------|--|-----|
| 3.1   | ECO No. 1 - Reduction of Monitor Exhaust<br>In Welding Area . . . . .  | 71  |
| 3.1.1 | Present Mode of Operation . . . . .  | 71  |
| 3.1.2 | Proposed Energy Saving Revision . . . . .  | 71  |
| 3.1.3 | Resultant Energy Savings . . . . .   | 72  |
| 3.1.4 | Implementation Costs . . . . .   | 76  |
| 3.1.5 | Classification . . . . .   | 77  |
| 3.2   | ECO No. 2 - Heat Recovery from Exhaust Air<br>in Vehicle Adjust Areas . . . . .  | 79  |
| 3.2.1 | Present Mode of Operation . . . . .  | 79  |
| 3.2.2 | Proposed Energy Saving Revision . . . . .  | 79  |
| 3.2.3 | Resultant Energy Savings . . . . .   | 80  |
| 3.2.4 | Implementation Costs . . . . .   | 86  |
| 3.2.5 | Classification . . . . .   | 87  |
| 3.3   | ECO No. 3 - Destratification of Plant Air . . . . .  | 89  |
| 3.3.1 | Present Mode of Operation . . . . .  | 89  |
| 3.3.2 | Proposed Energy Saving Revision . . . . .  | 89  |
| 3.3.3 | Resultant Energy Savings . . . . .   | 89  |
| 3.3.4 | Implementation Costs . . . . .   | 92  |
| 3.3.5 | Classification . . . . .   | 93  |
| 3.4   | Interactive Effects of ECO No. 1, ECO No. 2<br>and ECO No. 3, Welding Filter Installation,<br>Vehicle Adjust Heat Recovery and<br>Destratification . . . . . | 95  |
| 3.4.1 | Annual Energy Costs Incurred . . . . .   | 96  |
| 3.4.2 | Annual Non-energy Cost Effects . . . . .   | 97  |
| 3.4.3 | Implementation Costs . . . . .   | 98  |
| 3.4.4 | Classification . . . . .   | 98  |
| 3.5   | ECO No. 4 - Air Curtains at Doors No's. 12,<br>19, 20, 24, 25 and 37 . . . . .   | 100 |
| 3.5.1 | Present Mode of Operation . . . . .  | 100 |
| 3.5.2 | Proposed Energy Savings Revision . . . . .   | 100 |
| 3.5.3 | Resultant Energy Savings . . . . .   | 101 |
| 3.5.4 | Implementation Costs . . . . .   | 104 |
| 3.5.5 | Classification . . . . .   | 104 |

## NARRATIVE SUMMARY (cont'd.)

|  | <u>Page</u> |
|--|-------------|
| <br>3. IDENTIFICATION OF ECO's (cont'd.)                         |             |
| 3.6 ECO No. 5 - Storm Sash on Office Windows . . . . .           | 106         |
| 3.6.1 Present Mode of Operation . . . . .                        | 106         |
| 3.6.2 Proposed Energy Saving Revision . . . . .                  | 106         |
| 3.6.3 Resultant Energy Savings . . . . .                         | 106         |
| 3.6.4 Implementation Costs . . . . .                             | 109         |
| 3.6.5 Classification . . . . .                                   | 110         |
| 3.7 ECO No. 6 - Economizer for Office Area A/C Units . . . . .   | 112         |
| 3.7.1 Present Mode of Operation . . . . .                        | 112         |
| 3.7.2 Proposed Energy Saving Revision . . . . .                  | 112         |
| 3.7.3 Resultant Energy Savings . . . . .                         | 112         |
| 3.7.4 Implementation Costs . . . . .                             | 113         |
| 3.7.5 Classification . . . . .                                   | 113         |
| 3.8 ECO No. 7 - Replace DX Units with Rooftop Unit . . . . .     | 115         |
| 3.8.1 Present Mode of Operation . . . . .                        | 115         |
| 3.8.2 Proposed Energy Saving Revision . . . . .                  | 115         |
| 3.8.3 Resultant Energy Savings . . . . .                         | 115         |
| 3.8.4 Non-energy Savings . . . . .                               | 116         |
| 3.8.5 Implementation Costs . . . . .                             | 117         |
| 3.8.6 Classification . . . . .                                   | 117         |
| 3.9 ECO No. P-1 - Treatment Tank Insulation . . . . .            | 119         |
| 3.9.1 Present Mode of Operation . . . . .                        | 119         |
| 3.9.2 Proposed Energy Saving Revision . . . . .                  | 119         |
| 3.9.3 Resultant Energy Savings . . . . .                         | 119         |
| 3.9.4 Implementation Costs . . . . .                             | 123         |
| 3.9.5 Classification . . . . .                                   | 124         |
| 3.10 ECO No. P-2 - Treatment Tank Water Shut-off Valve . . . . . | 126         |
| 3.10.1 Present Mode of Operation . . . . .                       | 126         |
| 3.10.2 Proposed Energy Saving Revision . . . . .                 | 126         |
| 3.10.3 Resultant Energy Savings . . . . .                        | 126         |
| 3.10.4 Implementation Costs . . . . .                            | 129         |
| 3.10.5 Classification . . . . .                                  | 129         |

## NARRATIVE SUMMARY (cont'd.)

|   | <u>Page</u> |
|---|-------------|
| <b>3. IDENTIFICATION OF ECO's (cont'd.)</b>   |             |
| 3.11 ECO No. P-3 - Hot Water Rinse Heat Recovery . . . . .  | 133         |
| 3.11.1 Present Mode of Operation . . . . .  | 133         |
| 3.11.2 Proposed Energy Saving Revision . . . . .  | 133         |
| 3.11.3 Resultant Energy Savings . . . . .   | 133         |
| 3.11.4 Implementation Costs . . . . .   | 135         |
| 3.11.5 Classification . . . . .   | 135         |
| 3.12 ECO No. P-2 and ECO No. P-3 - Synergistic Effects . . . . .                                  | 138         |
| 3.12.1 Existing Energy Consumption of Rinse Water . . . . .                                       | 138         |
| 3.12.2 Rinse Water Energy Consumption After P-2 and P-3 . . . . .                                 | 138         |
| 3.12.3 Classification . . . . .   | 141         |
| 3.13 ECO No. P-4 - Treatment Tank Covers . . . . .  | 143         |
| 3.13.1 Present Mode of Operation . . . . .  | 143         |
| 3.13.2 Proposed Energy Saving Revision . . . . .  | 143         |
| 3.13.3 Resultant Energy Savings . . . . .   | 144         |
| 3.13.4 Implementation Costs . . . . .   | 147         |
| 3.13.5 Classification . . . . .   | 147         |
| <b>4. PROGRAMMING DOCUMENTATION . . . . .</b>   | <b>149</b>  |
| <b>5. ANNEX A</b>   |             |
| 5.1 Production Equipment Replacements, Modifications, Disposals . . . . .                         | 168         |
| 5.2 Energy Efficient Motors and Variable Frequency Drives . . . . .                               | 168         |
| 5.2.1 Estimate of Possible Energy Savings per Year Associated with Coolant System Pumps . . . . . | 168         |
| 5.2.2 Energy Efficiency Motor Study . . . . .   | 170         |
| 5.2.3 Variable Frequency Drives . . . . .   | 203         |
| 5.3 Scheduling/Loading of Production Equipment . . . . .  | 203         |



## NARRATIVE SUMMARY (cont'd.)

|  | <u>Page</u> |
|--|-------------|
| 5. ANNEX A (cont'd.)   |             |
| 5.4 Waste Heat Recovery from Industrial Processes . . . . .  | 203         |
| 5.5 Automated Control of Production Equipment . .  | 204         |
| 5.6 Improve Facility Layout and Space Utilization . . . . .  | 204         |
| 5.7 Solar Applications . . . . .   | 204         |
| 5.8 Consolidate Processes and Equipment Requiring Special Environments . . . . .   | 204         |
| 5.9 Building Ventilation, Exhaust Systems . . . .  | 205         |
| 5.10 Production Ventilation, Exhaust Systems . . .   | 205         |
| 5.11 Improved Methods/Controls to Reduce Scrap, Rework, and "Goldplating", which Consume Energy without Contributing to Production Mission . . . . . | 205         |
| 5.12 Steam Distribution and Condensate Return System . . . . .   | 210         |
| 5.13 Compressed Air Distribution System . . . . .  | 210         |
| 5.14 Lighting Control . . . . .  | 210         |
| 5.15 Electrical Distribution . . . . .   | 210         |
| 5.16 Airlocks for Seven Exterior Train and Truck Openings . . . . .  | 211         |
| 5.17 Gas or Electric Radiant Heating on Shipping Dock . . . . .  | 211         |
| 6. FACILITY ENERGY CONSUMPTION   |             |
| 6.1 Historical Energy Consumption . . . . .  | 212         |
| 6.1.1 Introduction . . . . .   | 212         |
| 6.1.2 Electrical Consumption . . . . .   | 212         |
| 6.1.3 Natural Gas Consumption . . . . .  | 212         |
| 6.1.4 Steam Consumption . . . . .  | 217         |
| 6.1.5 Historical Energy Conclusions . . .  | 230         |

## NARRATIVE SUMMARY (cont'd.)

### Page

## 6. FACILITY ENERGY CONSUMPTION (cont'd.)

|       |   |     |
|-------|---|-----|
| 6.2   | Current Energy Consumption . . . . .                                      | 237 |
| 6.2.1 | Introduction . . . . .  | 237 |
| 6.2.2 | Current Electrical Consumption . . . . .                                  | 237 |
| 6.2.3 | Current Natural Gas Consumption . . . . .                                 | 267 |
| 6.2.4 | Current Steam Consumption . . . . .                                       | 267 |
| 6.2.5 | Conclusions . . . . .   | 267 |
| 6.3   | Energy Consumption After Implementation of<br>Recommended ECO's . . . . . | 273 |
| 6.3.1 | Introduction . . . . .  | 273 |
| 6.3.2 | Electrical Consumption . . . . .  | 273 |
| 6.3.3 | Natural Gas Consumption . . . . .   | 273 |
| 6.3.4 | Coal Consumption . . . . .  | 280 |
| 6.3.5 | Conclusions . . . . .   | 280 |
| 6.4   | Energy Consumption at Full Utilization . . . . .                          | 291 |
| 6.4.1 | Introduction . . . . .  | 291 |
| 6.4.2 | Recommended ECO's . . . . .   | 291 |
| 6.4.3 | Electrical Consumption . . . . .  | 298 |
| 6.4.4 | Natural Gas Consumption . . . . .   | 298 |
| 6.4.5 | Coal Consumption . . . . .  | 306 |
| 6.4.6 | Total Energy Consumption . . . . .  | 306 |
| 6.5   | Projected Energy Costs . . . . .  | 312 |

## APPENDIX A

|  | <u>Page</u> |
|--|-------------|
| A. BUILDING 4 ENERGY COSTS . . . . .               | AA-1        |
| B. BOILER HOUSE REPORT SUMMARY . . . . .           | AB-1        |
| C. SOLAR RADIATION DATA . . . . .                  | AC-1        |
| D. PRIOR ECO DOCUMENTATION                         |             |
| Project F-5 . . . . .                              | AD-1        |
| Project B-1 . . . . .                              | AD-31       |
| Project F-2 . . . . .                              | AD-94       |
| E. TRACE OUTPUT                                    |             |
| Trace Computer Simulation Model . . . . .          | AE-1        |
| Trane "Trace" Computer Model Documentation         |             |
| Introduction to Trace Version 500 . . . . .        | AE-4        |
| Trace Version 500 . . . . .                        | AE-26       |
| Load Phase . . . . .                               | AE-40       |
| System Simulation Phase Documentation . . . . .    | AE-57       |
| Sample Input Prompts . . . . .                     | AE-67       |
| Computer Runs                                      |             |
| Computer Run No. 1 . . . . .                       | AE-68       |
| Computer Run No. 2 . . . . .                       | AE-108      |
| Computer Run No. 3 . . . . .                       | AE-151      |
| Computer Run No. 4 . . . . .                       | AE-194      |
| F. MANUFACTURERS DATA                              |             |
| ECO No. 1 - Welding Filter Installation . . . . .  | AF-1        |
| ECO No. 2 - Vehicle Adjust Heat Recovery . . . . . | AF-5        |
| ECO No. 3 - Destratification of Plant              |             |
| Air . . . . .                                      | AF-9        |
| ECO No. 4 - Air Curtains . . . . .                 | AF-11       |

## APPENDIX B

|   | <u>Page</u> |
|---|-------------|
| A. SCOPE OF WORK . . . . .                  | BA-1        |
| B. PRENEGOTIATION MEETING MINUTES . . . . . | BB-1        |
| C. PS&ER REPORTS . . . . .                  | BC-1        |
| D. SELFRIDGE BIN DATA . . . . .             | BD-1        |
| E. SURVEY FORMS . . . . .                   | BE-1        |
| F. ZONE INFORMATION . . . . .               | BF-1        |

## LIST OF FIGURES

|  | <u>Page</u> |
|--|-------------|
| Figure 1.1: ENERGY HISTORY - BLDG 4, Total Energy<br>9/82 - 3/85           | 4           |
| Figure 1.2: ENERGY HISTORY - BLDG 4, Total Source<br>Energy 9/82 - 3/85    | 5           |
| Figure 1.3: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Electricity           | 15          |
| Figure 1.4: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Natural Gas - Process | 16          |
| Figure 1.5: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Steam                 | 17          |
| Figure 1.6: PROJECTED CURRENT ENERGY CONSUMPTION                           | 20          |
| Figure 1.7: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Total Source Energy   | 21          |
| Figure 1.8: TOTAL ENERGY REDUCTION, ECO 1, 2 & 3                           | 48          |
| Figure 1.9: TOTAL ENERGY REDUCTION, ECO 4                                  | 49          |
| Figure 1.10: TOTAL ENERGY REDUCTION, ECO 5                                 | 50          |
| Figure 1.11: TOTAL ENERGY REDUCTION, ECO P1                                | 51          |
| Figure 1.12: TOTAL ENERGY REDUCTION, ECO P2 & P3                           | 52          |
| Figure 1.13: TOTAL ENERGY REDUCTION, ECO P4                                | 53          |
| Figure 1.14: TOTAL ELECTRICAL CONSUMPTION, All<br>Proposed ECO's           | 57          |
| Figure 1.15: TOTAL NATURAL GAS CONSUMPTION, All<br>Proposed ECO's          | 61          |
| Figure 1.16: TOTAL COAL CONSUMPTION, All Proposed<br>ECO's                 | 64          |
| Figure 1.17: TOTAL ENERGY CONSUMPTION, All Proposed<br>ECO's               | 68          |

**NARRATIVE SUMMARY**  
**LIST OF FIGURES**

|   | <u>Page</u> |
|---|-------------|
| Figure 1.1: ENERGY HISTORY - BLDG. 4, Total Energy 9/82 - 3/85          | 4           |
| Figure 1.2: ENERGY HISTORY - BLDG. 4, Total Source Energy 9/82 - 3/85   | 5           |
| Figure 1.3: PROJECTED CURRENT ENERGY CONSUMPTION, Electricity           | 14          |
| Figure 1.4: PROJECTED CURRENT ENERGY CONSUMPTION, Natural Gas - Process | 15          |
| Figure 1.5: PROJECTED CURRENT ENERGY CONSUMPTION, Steam                 | 17          |
| Figure 1.6: PROJECTED CURRENT ENERGY CONSUMPTION                        | 19          |
| Figure 1.7: PROJECTED CURRENT ENERGY CONSUMPTION, Total Source Energy   | 20          |
| Figure 1.8: TOTAL ENERGY REDUCTION, ECO 1, 2 & 3                        | 43          |
| Figure 1.9: TOTAL ENERGY REDUCTION, ECO 4                               | 44          |
| Figure 1.10: TOTAL ENERGY REDUCTION, ECO 5                              | 45          |
| Figure 1.11: TOTAL ENERGY REDUCTION, ECO P1                             | 46          |
| Figure 1.12: TOTAL ENERGY REDUCTION, ECO P2 & P3                        | 47          |
| Figure 1.13: TOTAL ENERGY REDUCTION, ECO P4                             | 48          |
| Figure 1.14: TOTAL ELECTRICAL CONSUMPTION, All Proposed ECO's           | 52          |
| Figure 1.15: TOTAL NATURAL GAS CONSUMPTION, All Proposed ECO's          | 55          |
| Figure 1.16: TOTAL COAL CONSUMPTION, All Proposed ECO's                 | 59          |
| Figure 1.17: TOTAL ENERGY CONSUMPTION, All Proposed ECO's               | 63          |

## NARRATIVE SUMMARY

### LIST OF FIGURES (cont'd.)

|   | <u>Page</u> |
|---|-------------|
| Figure 5.1: ENERGY EFFICIENT MOTOR STUDY, for<br>1 HP Motor     | 176         |
| Figure 5.2: ENERGY EFFICIENT MOTOR STUDY, for<br>1-1/2 HP Motor | 178         |
| Figure 5.3: ENERGY EFFICIENT MOTOR STUDY, for<br>2 HP Motor     | 180         |
| Figure 5.4: ENERGY EFFICIENT MOTOR STUDY, for<br>3 HP Motor     | 182         |
| Figure 5.5: ENERGY EFFICIENT MOTOR STUDY, for<br>5 HP Motor     | 184         |
| Figure 5.6: ENERGY EFFICIENT MOTOR STUDY, for<br>7.5 HP Motor   | 186         |
| Figure 5.7: ENERGY EFFICIENT MOTOR STUDY, for<br>10 HP Motor    | 188         |
| Figure 5.8: ENERGY EFFICIENT MOTOR STUDY, for<br>15 HP Motor    | 190         |
| Figure 5.9: ENERGY EFFICIENT MOTOR STUDY, for<br>20 HP Motor    | 192         |
| Figure 5.10: ENERGY EFFICIENT MOTOR STUDY, for<br>25 HP Motor   | 194         |
| Figure 5.11: ENERGY EFFICIENT MOTOR STUDY, for<br>30 HP Motor   | 196         |
| Figure 5.12: ENERGY EFFICIENT MOTOR STUDY, for<br>40 HP Motor   | 198         |
| Figure 5.13: ENERGY EFFICIENT MOTOR STUDY, for<br>50 HP Motor   | 200         |
| Figure 5.14: ENERGY EFFICIENT MOTOR STUDY, for<br>60 HP Motor   | 202         |
| Figure 5.15: QUALITY, Detroit #2, Rework Hours/<br>Unit - M60   | 206         |
| Figure 5.16: QUALITY, Detroit #2, Rework Hours/<br>Unit - M1    | 207         |

**NARRATIVE SUMMARY**  
**LIST OF FIGURES (cont'd.)**

|  | <u>Page</u> |
|--|-------------|
| Figure 5.17: TOP REINSPECTION ITEMS  | 208         |
| Figure 5.18: SCRAP (LABOR), DETROIT TANK PLANT                                   | 209         |
| Figure 6.1: ENERGY HISTORY - BLDG. 4, Electrical<br>Consumption 9/82 - 3/85      | 213         |
| Figure 6.2: ENERGY HISTORY - BLDG. 4, Gas<br>Consumption 9/82 - 3/85             | 215         |
| Figure 6.3: STEAM PRODUCTION, 9/82 - 3/85  | 218         |
| Figure 6.4: STEAM DISTRIBUTION SYSTEM  | 220         |
| Figure 6.5: ENERGY HISTORY - BLDG. 4, Heating<br>& Ventilation Steam 9/82 - 3/85 | 231         |
| Figure 6.6: ENERGY HISTORY - BLDG. 4, Base<br>Steam 9/82 - 3/85                  | 232         |
| Figure 6.7: ENERGY HISTORY - BLDG. 4, Total<br>Steam 9/82 - 3/85                 | 233         |
| Figure 6.8: ENERGY HISTORY - BLDG. 4, Total<br>Energy 9/82 - 3/85                | 234         |
| Figure 6.9: ENERGY HISTORY - BLDG. 4, Total<br>Source Energy 9/82 - 3/85         | 235         |
| Figure 6.10: ENERGY HISTORY - BLDG. 4, Total<br>Source Energy 9/82 - 3/85        | 236         |
| Figure 6.11: ELECTRICAL PROFILE, Monday<br>April 15, 1985                        | 245         |
| Figure 6.12: ELECTRICAL PROFILE, Tuesday<br>April 16, 1985                       | 246         |
| Figure 6.13: ELECTRICAL PROFILE, Wednesday<br>April 17, 1985                     | 247         |
| Figure 6.14: ELECTRICAL PROFILE, Thursday<br>April 18, 1985                      | 248         |



**NARRATIVE SUMMARY**  
**LIST OF FIGURES (cont'd.)**

|  | <u>Page</u> |
|--|-------------|
| Figure 6.15: ELECTRICAL PROFILE, Friday<br>April 19, 1985                    | 249         |
| Figure 6.16: ELECTRICAL PROFILE, Saturday<br>April 20, 1985                  | 250         |
| Figure 6.17: ELECTRICAL PROFILE, Sunday<br>April 21, 1985                    | 251         |
| Figure 6.18: ELECTRICAL PROFILE, Average Weekday                             | 253         |
| Figure 6.19: ELECTRICAL PROFILE, Daily Data                                  | 255         |
| Figure 6.20: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Electricity            | 258         |
| Figure 6.21: ELECTRICAL PROFILE, Sunday Super-<br>imposed on Average Weekday | 259         |
| Figure 6.22: ELECTRICAL PROFILE, Average Weekday<br>Less Sunday              | 269         |
| Figure 6.23: ELECTRICAL PROFILE, Average Weekday                             | 262         |
| Figure 6.24: ELECTRICAL PROFILE, Production                                  | 263         |
| Figure 6.25: ELECTRICAL PROFILE, Production                                  | 265         |
| Figure 6.26: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Natural Gas - Process  | 268         |
| Figure 6.27: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Steam                  | 269         |
| Figure 6.28: PROJECTED CURRENT ENERGY CONSUMPTION                            | 270         |
| Figure 6.29: PROJECTED CURRENT ENERGY CONSUMPTION,<br>Total Source Energy    | 271         |
| Figure 6.30: TOTAL ELECTRIAL CONSUMPTION, All<br>Proposed ECO's              | 276         |
| Figure 6.31: TOTAL NATURAL GAS CONSUMPTION, All<br>Proposed ECO's            | 279         |
| Figure 6.32: TOTAL COAL CONSUMPTION, All Proposed<br>ECO's                   | 283         |

**NARRATIVE SUMMARY**  
**LIST OF FIGURES (cont'd.)**

|  | <u>Page</u> |
|--|-------------|
| Figure 6.33: TOTAL ENERGY CONSUMPTION, All<br>Proposed ECO's             | 286         |
| Figure 6.34: TOTAL ENERGY CONSUMPTION,<br>Implementation of ECO 1        | 287         |
| Figure 6.35: TOTAL ENERGY CONSUMPTION,<br>Implementation of ECO 2        | 288         |
| Figure 6.36: TOTAL ENERGY CONSUMPTION,<br>Implementation of ECO 3        | 289         |
| Figure 6.37: TOTAL ENERGY CONSUMPTION,<br>Implementation of ECO 1, 2 & 3 | 290         |
| Figure 6.38: ELECTRICAL CONSUMPTION, Full<br>Utilization                 | 300         |
| Figure 6.39: NATURAL GAS CONSUMPTION, Full<br>Utilization                | 305         |
| Figure 6.40: COAL CONSUMPTION, Full Utilization                          | 309         |
| Figure 6.41: TOTAL ENERGY CONSUMPTION, Full<br>Utilization               | 311         |

## LIST OF TABLES

|  | <u>Page</u> |
|--|-------------|
| Table 1.1: ELECTRICAL CONSUMPTION - HISTORICAL       | 6           |
| Table 1.2: NATURAL GAS CONSUMPTION - HISTORICAL      | 7           |
| Table 1.3: EAST SITE STEAM CONSUMPTION               | 9           |
| Table 1.4: BUILDING 4 STEAM CONSUMPTION              | 10          |
| Table 1.5: FY 83 CONSUMPTION                         | 11          |
| Table 1.6: ELECTRICAL ENERGY PROFILE (MWH)           | 13          |
| Table 1.7: BUILDING 4 HEATING AND VENTILATION LOAD   | 19          |
| Table 1.8: DATP PROJECTED CURRENT ENERGY CONSUMPTION | 22          |
| Table 1.9: SUMMARY OF INVESTIGATED ECO's             | 31          |
| Table 1.10: SUMMARY OF RECOMMENDED ECO's             | 46          |
| Table 1.11: SYNERGISTIC EFFECTS OF RECOMMENDED ECO's | 47          |
| Table 1.12: CHANGE IN ELECTRICAL CONSUMPTION         | 55          |
| Table 1.13: TOTAL ELECTRICAL CONSUMPTION             | 56          |
| Table 1.14: CHANGE IN NATURAL GAS CONSUMPTION        | 59          |
| Table 1.15: TOTAL NATURAL GAS CONSUMPTION            | 60          |
| Table 1.16: CHANGE IN COAL CONSUMPTION               | 62          |
| Table 1.17: TOTAL COAL CONSUMPTION                   | 63          |
| Table 1.18: CHANGE IN ENERGY CONSUMPTION - ALL ECO's | 65          |
| Table 1.19: TOTAL ENERGY CONSUMPTION                 | 67          |

**NARRATIVE SUMMARY  
LIST OF TABLES**

|   | <u>Page</u> |
|---|-------------|
| Table 1.1: ELECTRICAL CONSUMPTION - HISTORICAL          | 6           |
| Table 1.2: NATURAL GAS CONSUMPTION - HISTORICAL         | 7           |
| Table 1.3: EAST SITE STEAM CONSUMPTION                  | 8           |
| Table 1.4: BUILDING 4 STEAM CONSUMPTION                 | 9           |
| Table 1.5: FY 83 CONSUMPTION                            | 11          |
| Table 1.6: ELECTRICAL ENERGY PROFILE                    | 13          |
| Table 1.7: BUILDING 4 HEATING AND VENTILATION<br>LOAD   | 18          |
| Table 1.8: DATP PROJECTED CURRENT ENERGY<br>CONSUMPTION | 21          |
| Table 1.9: SUMMARY OF INVESTIGATED ECO's                | 29          |
| Table 1.10: SUMMARY OF RECOMMENDED ECO's                | 41          |
| Table 1.11: SYNERGISTIC EFFECTS OF RECOMMENDED<br>ECO's | 42          |
| Table 1.12: CHANGE IN ELECTRICAL CONSUMPTION            | 50          |
| Table 1.13: TOTAL ELECTRICAL CONSUMPTION                | 51          |
| Table 1.14: CHANGE IN NATURAL GAS CONSUMPTION           | 53          |
| Table 1.15: TOTAL NATURAL GAS CONSUMPTION               | 54          |
| Table 1.16: CHANGE IN COAL CONSUMPTION                  | 57          |
| Table 1.17: TOTAL COAL CONSUMPTION                      | 58          |
| Table 1.18: CHANGE IN ENERGY CONSUMPTION - ALL<br>ECO's | 60          |
| Table 1.19: TOTAL ENERGY CONSUMPTION                    | 62          |

**NARRATIVE SUMMARY**  
**LIST OF TABLES (cont'd.)**

|   | <u>Page</u> |
|---|-------------|
| Table 3.1: TREATMENT TANK INSULATION                  | 120         |
| Table 5.1: STANDARD MOTOR SIZES AND ACCOMPANYING DATA | 172         |
| Table 5.2: HIGH EFFICIENCY MOTOR STUDY                | 175         |
| Table 5.3: HIGH EFFICIENCY MOTOR STUDY                | 177         |
| Table 5.4: HIGH EFFICIENCY MOTOR STUDY                | 179         |
| Table 5.5: HIGH EFFICIENCY MOTOR STUDY                | 181         |
| Table 5.6: HIGH EFFICIENCY MOTOR STUDY                | 183         |
| Table 5.7: HIGH EFFICIENCY MOTOR STUDY                | 185         |
| Table 5.8: HIGH EFFICIENCY MOTOR STUDY                | 187         |
| Table 5.9: HIGH EFFICIENCY MOTOR STUDY                | 189         |
| Table 5.10: HIGH EFFICIENCY MOTOR STUDY               | 191         |
| Table 5.11: HIGH EFFICIENCY MOTOR STUDY               | 193         |
| Table 5.12: HIGH EFFICIENCY MOTOR STUDY               | 195         |
| Table 5.13: HIGH EFFICIENCY MOTOR STUDY               | 197         |
| Table 5.14: HIGH EFFICIENCY MOTOR STUDY               | 199         |
| Table 5.15: HIGH EFFICINECY MOTOR STUDY               | 201         |
| Table 6.1: ELECTRICAL CONSUMPTION - HISTORICAL        | 214         |
| Table 6.2: NATURAL GAS CONSUMPTION - HISTORICAL       | 216         |
| Table 6.3 EAST SITE STEAM CONSUMPTION                 | 219         |
| Table 6.4 EAST SITE BUILDINGS                         | 221         |

**NARRATIVE SUMMARY**  
**LIST OF TABLES (cont'd.)**

|  | <u>Page</u> |
|--|-------------|
| Table 6.5: EAST SITE BUILDING HEAT LOAD COEFFICIENTS               | 222         |
| Table 6.6: EAST SITE MONTHLY BUILDING HEAT LOADS                   | 223         |
| Table 6.7: HEAT LOAD CORRECTION FACTORS - HISTORICAL               | 225         |
| Table 6.8: CORRECTED MONTHLY HEAT LOAD OF EAST SITE BUILDINGS      | 226         |
| Table 6.9: BUILDING 4 STEAM CONSUMPTION                            | 227         |
| Table 6.10: BASE STEAM   | 228         |
| Table 6.11: BUILDING 4 HEATING AND VENTILATION LOAD                | 229         |
| Table 6.12: ELECTRICAL ENERGY PROFILE FOR MONDAY APRIL 15, 1985    | 238         |
| Table 6.13: ELECTRICAL ENERGY PROFILE FOR TUESDAY APRIL 16, 1985   | 239         |
| Table 6.14: ELECTRICAL ENERGY PROFILE FOR WEDNESDAY APRIL 17, 1985 | 240         |
| Table 6.15: ELECTRICAL ENERGY PROFILE FOR THURSDAY APRIL 18, 1985  | 241         |
| Table 6.16: ELECTRICAL ENERGY PROFILE FOR FRIDAY APRIL 19, 1985    | 242         |
| Table 6.17: ELECTRICAL ENERGY PROFILE FOR SATURDAY APRIL 20, 1985  | 243         |
| Table 6.18: ELECTRICAL ENERGY PROFILE FOR SUNDAY APRIL 21, 1985    | 244         |
| Table 6.19: ELECTRICAL ENERGY PROFILE FOR AVERAGE WEEKDAY          | 252         |
| Table 6.20: ELECTRICAL ENERGY PROFILE                              | 254         |
| Table 6.21: DATP PROJECTED CURRENT ENERGY CONSUMPTION              | 257         |

**NARRATIVE SUMMARY**  
**LIST OF TABLES (cont'd.)**

|   | <u>Page</u> |
|---|-------------|
| Table 6.22: CHANGE IN ELECTRICAL CONSUMPTION  | 274         |
| Table 6.23: TOTAL ELECTRICAL CONSUMPTION  | 275         |
| Table 6.24: CHANGE IN NATURAL GAS CONSUMPTION   | 277         |
| Table 6.25: TOTAL NATURAL GAS CONSUMPTION   | 278         |
| Table 6.26: CHANGE IN COAL CONSUMPTION  | 281         |
| Table 6.27: TOTAL COAL CONSUMPTION  | 282         |
| Table 6.28: CHANGE IN ENERGY CONSUMPTION -<br>ALL ECO's                                   | 284         |
| Table 6.29: TOTAL ENERGY CONSUMPTION  | 285         |
| Table 6.30: MONTHLY ELECTRICAL USAGE ECO No's.<br>1, 2 and 3 UNDER FULL UTILIZATION       | 294         |
| Table 6.31: ELECTRICAL CONSUMPTION REDUCTION  | 299         |
| Table 6.32: MONTHLY HEATING AND VENTILATION LOAD  | 301         |
| Table 6.33: HV STEAM - SOURCE COMPONENTS  | 302         |
| Table 6.34: NATURAL GAS CONSUMPTION FULL<br>UTILIZATION                                   | 303         |
| Table 6.35: NATURAL GAS CONSUMPTION REDUCTION   | 304         |
| Table 6.36: COAL CONSUMPTION  | 307         |
| Table 6.37: COAL CONSUMPTION REDUCTION  | 308         |
| Table 6.38: ENERGY REDUCTION AT FULL UTILIZATION  | 310         |
| Table 6.39: FORECAST PRICES OF ENERGY FOR MICHIGAN<br>BY FUEL TYPE, NOMINAL DOLLARS       | 313         |
| Table 6.40: FORECAST PRICES OF ENERGY FOR MICHIGAN<br>BY FUEL TYPE, CONSTANT 1983 DOLLARS | 314         |
| Table 6.41: FORECAST PRICE ESTIMATES FOR BUILDING<br>4 BY FUEL TYPE                       | 315         |

## 1. EXECUTIVE SUMMARY

### 1.1 Introduction

The Detroit Arsenal Tank Plant is located in Warren, Michigan, a suburb of Detroit. The Detroit Arsenal, of which the tank plant is a part, is the headquarters for U. S. Army Tank Automotive Command (TACOM). The total facility has 105 buildings, the tank plant, Building 4, is the largest at 1,114,000 square feet.

Building 4 is the final assembly facility for the production of M1 and M60 tanks. Components and subassemblies are shipped from subcontractors and the Lima, Ohio tank facility for final assembly at the Warren, Michigan facility. The main function of the plant is assembly with related support areas such as heat treat, welding, painting and machining.

The plant has been producing tanks since 1941 when the first M3 tank was delivered in April and with full production starting in July. The plant has produced M3, M4, M47, M48, M60, M60H2 and M1 tanks since 1941 to the present. Prior to General Dynamics taking over the operation in 1982, the facility was operated by Chrysler Corporation.

The original concept was based on the automotive industry assembly line and was very successful for many years in turning out very high volumes of tanks. With the increasing complexity of the tank due to modern technology, the volume decreased substantially until today, the assembly of the tanks is more of a job shop operation rather than a fast



moving assembly line operation. The plant is operated on three shifts, five days a week. The third shift is not a full shift.

Since energy costs have risen dramatically from 1973 and future projections indicate that these costs will continue to rise, energy conservation measures need to be implemented to hold down the operating costs of the facility. Building 4 at the Detroit Arsenal has many varied environmental and process systems that offer the possibility of energy conservation opportunities to be identified, quantified and offered for consideration for implementation through an energy conservation analysis. Smith, Hinchman & Grylls Associates, Inc. of Detroit, Michigan was commissioned to perform this analysis on Building 4.

The heating media for the facility is low pressure steam. Air handling units with heating coils and unit heaters provide the heating requirements. Building and process ventilation is provided by dedicated exhaust systems and through the building monitor system. Cooling is provided for specialized areas such as computer rooms, testing and the general offices.

In performing the energy conservation analysis, many on-site visits were made to gather data of present and past energy use, to interview facility operating personnel on the mode of operation of the facility, and to survey and record data pertaining to Building 4 HVAC and process equipment.

The following report is the result of the energy conservation analysis.

## 1.2 Historical Energy Consumption

### 1.2.1 Introduction

The recorded energy history is useful for predicting energy consumption when production levels change or when energy conservation opportunities are implemented. Building 4 lacks a good base of energy consumption data. Data was obtained from the boiler house reports for the period September 1982 to March 1985. Because of the lack of positive metering, this data is used as a basis of analysis, but should be updated once a positive metering program is implemented. (See Facility Energy Consumption, Section 6 of Narrative Summary.) The energy history for Building 4 is presented graphically in Figure 1.1 and Figure 1.2.

Figure 1.1 shows consumption in terms of type of energy consumed at Building 4 and Figure 1.2 is in terms of source energy.

### 1.2.2 Electrical Consumption

Electrical consumption records are kept at the boiler house (see Boiler House Report Summary, Appendix A, Section B). A summary of the electrical consumption data is presented in Table 1.1. Monthly consumption ranged from 1,996,000 kWH in July 1983 to 3,448,800 kWH in February 1984.


### 1.2.3 Natural Gas Consumption

Natural gas is consumed at Building 4 in the heat/surface treatment area. Gas consumption is metered to Building 4 and is recorded at the boiler house (see Boiler House Report Summary, Appendix A, Section B). Monthly consumption ranged from 38,000 cubic feet in December 1984 to 398,500 cubic feet in May 1985 (see Table 1.2).

Figure 1.1

# ENERGY HISTORY-BLDG 4

TOTAL ENERGY 9/82-3/85




\* NOTE: Gas is a small portion of monthly energy consumption and is barely visible at the bottom of the graph.

Figure 1.2

# ENERGY HISTORY-BLDG 4

TOTAL SOURCE ENERGY 9/82-3/85



\* NOTE: In this graph, "gas" consists of two components--production and steam generation.

Table 1.1

## ELECTRICAL CONSUMPTION - HISTORICAL

| <u>Month</u> | <u>Consumption</u><br><u>kWH</u> | <u>Consumption</u><br><u>10<sup>6</sup> Btu*</u> |
|--------------|----------------------------------|--|
| Sep 1982     | 2,296,800                        | 26,642.88  |
| Oct          | 2,613,600                        | 30,317.76  |
| Nov          | 2,630,400                        | 30,512.64  |
| Dec          | 2,419,200                        | 28,062.72  |
| Jan 1983     | 2,942,400                        | 34,131.84  |
| Feb          | 2,677,333                        | 31,057.06  |
| Mar          | 2,677,333                        | 31,057.06  |
| Apr          | 2,677,333                        | 31,057.06  |
| May          | 2,488,800                        | 28,870.08  |
| Jun          | 3,136,800                        | 36,386.88  |
| Jul          | 1,996,800                        | 23,162.88  |
| Aug          | 2,565,600                        | 29,760.96  |
| Sep          | 2,496,000                        | 28,953.60  |
| Oct          | 2,412,000                        | 27,979.20  |
| Nov          | 2,440,800                        | 28,313.28  |
| Dec          | 2,719,200                        | 31,542.72  |
| Jan 1984     | 2,877,600                        | 33,380.16  |
| Feb          | 3,448,800                        | 40,006.08  |
| Mar          | 2,697,600                        | 31,292.16  |
| Apr          | 3,016,800                        | 34,994.88  |
| May          | 2,450,400                        | 28,424.64  |
| Jun          | 2,692,800                        | 31,236.48  |
| Jul          | 3,170,400                        | 36,776.64  |
| Aug          | 2,232,000                        | 25,891.20  |
| Sep          | 2,820,000                        | 32,712.00  |
| Oct          | 2,707,200                        | 31,403.52  |
| Nov          | 2,534,400                        | 29,399.04  |
| Dec          | 2,764,800                        | 32,071.68  |
| Jan 1985     | 3,043,200                        | 35,301.12  |
| Feb          | 2,918,400                        | 33,853.44  |
| Mar          | 2,779,200                        | 32,238.72  |

\* 11,600 Btu = 1 kWH

Table 1.2

## NATURAL GAS CONSUMPTION - HISTORICAL

| <u>Month</u> | <u>Consumption</u><br><u>cf</u> | <u>Consumption</u><br><u>10<sup>6</sup> Btu*</u> |
|--------------|---------------------------------|--|
| Sep 1982     | 309,013                         | 318.59   |
| Oct          | 334,700                         | 345.08   |
| Nov          | 245,600                         | 253.21   |
| Dec          | 184,800                         | 190.53   |
| Jan 1983     | 154,700                         | 159.50   |
| Feb          | 285,360                         | 294.21   |
| Mar          | 202,700                         | 208.98   |
| Apr          | 294,000                         | 303.11   |
| May          | 294,000                         | 303.11   |
| Jun          | 265,900                         | 274.14   |
| Jul          | 140,400                         | 144.75   |
| Aug          | 103,100                         | 106.30   |
| Sep          | 112,700                         | 116.19   |
| Oct          | 154,600                         | 159.39   |
| Nov          | 150,300                         | 154.96   |
| Dec          | 144,900                         | 149.39   |
| Jan 1984     | 186,800                         | 192.59   |
| Feb          | 149,700                         | 154.34   |
| Mar          | 116,800                         | 120.42   |
| Apr          | 66,900                          | 68.97  |
| May          | 86,800                          | 89.49  |
| Jun          | 132,000                         | 136.09   |
| Jul          | 80,700                          | 83.20  |
| Aug          | 156,800                         | 161.66   |
| Sep          | 169,000                         | 174.24   |
| Oct          | 218,300                         | 225.07   |
| Nov          | 206,400                         | 212.80   |
| Dec          | 38,000                          | 39.18  |
| Jan 1985     | 302,100                         | 311.47   |
| Feb          | 355,700                         | 366.73   |
| Mar          | 398,500                         | 410.85   |

\* 1,031 Btu = 1 cf

#### 1.2.4 Steam Consumption

Steam is not directly metered to Building 4. Total steam production is recorded at the boiler house and steam is metered to the west site of the facility. The difference is the amount charged to General Dynamics (see Table 1.3). The amount of steam used by General Dynamics represents the total steam used on the east site. In an attempt to isolate Building 4 from the east site consumption, the annual heating load of all east site buildings was calculated. This was subtracted from the east site total steam consumption to yield Building 4 steam consumption (see Table 1.4). Because of the method of steam metering used, this consumption includes Building 4 base steam as well as the steam utilized within the boiler house.

#### 1.2.5. FY 83 Consumption

The energy consumption for FY 83 is shown in Table 1.5. Total energy consumption for FY 83 is  $688,392.37 \times 10^6$  Btu. This translates into the following ratios:

$$\frac{688,392.37 \times 10^6 \text{ Btu/yr.}}{1,114,381 \text{ sf}} = 617,735.23 \text{ Btu/sf/yr.}$$

$$\frac{688,392.37 \times 10^6 \text{ Btu/yr.}}{\frac{60 \text{ tanks}}{\text{mo.}} \times 12 \text{ mos.}} = 956.1 \times 10^6 \text{ Btu/tank}$$

Table 1.3

## EAST SITE STEAM CONSUMPTION

| <u>Month</u> | <u>Consumption</u><br><u>10<sup>6</sup> lbs.</u> |
|--------------|--|
| Sep 1982     | 7.980  |
| Oct          | 23.036   |
| Nov          | 42.558   |
| Dec          | 43.869   |
| Jan 1983     | 45.184   |
| Feb          | 34.196   |
| Mar          | 41.659   |
| Apr          | 50.191   |
| May          | 28.276   |
| Jun          | 18.911   |
| Jul          | 12.298   |
| Aug          | 11.057   |
| Sep          | 12.818   |
| Oct          | 14.712   |
| Nov          | 31.233   |
| Dec          | 79.535   |
| Jan 1984     | 72.756   |
| Feb          | 48.091   |
| Mar          | 48.695   |
| Apr          | 29.361   |
| May          | 31.982   |
| Jun          | 18.528   |
| Jul          | 15.399   |
| Aug          | 13.475   |
| Sep          | 16.547   |
| Oct          | 21.285   |
| Nov          | 41.198   |
| Dec          | 53.313   |
| Jan 1985     | 66.712   |
| Feb          | 59.973   |
| Mar          | 51.425   |



Table 1.4

**BUILDING 4 STEAM CONSUMPTION**

| <u>Month</u> | <u>East Site<br/>Total<br/>10<sup>6</sup> lbs.</u> | <u>East Site<br/>Buildings<br/>Less #4<br/>10<sup>6</sup> lbs.</u> | <u>Building 4<br/>Consumption<br/>10<sup>6</sup> lbs.</u> | <u>Consumption<br/>10<sup>6</sup> Btu*</u> |
|--------------|--|--|---|--|
| Sep 1982     | 7.928  | 0.496  | 7.432   | 7,432                                      |
| Oct          | 23.036   | 1.613  | 21.423  | 21,423                                     |
| Nov          | 42.558   | 2.995  | 39.563  | 39,563                                     |
| Dec          | 43.869   | 4.108  | 39.761  | 39,761                                     |
| Jan 1983     | 45.184   | 5.929  | 39.255  | 39,255                                     |
| Feb          | 34.196   | 4.655  | 29.541  | 29,541                                     |
| Mar          | 41.659   | 4.274  | 37.385  | 37,385                                     |
| Apr          | 50.191   | 3.550  | 46.641  | 46,641                                     |
| May          | 28.276   | 2.065  | 26.211  | 26,211                                     |
| Jun          | 18.911   | 0  | 18.411  | 18,411                                     |
| Jul          | 12.298   | 0  | 12.298  | 12,298                                     |
| Aug          | 11.057   | 0  | 11.057  | 11,057                                     |
| Sep          | 12.818   | 0.655  | 12.163  | 12,163                                     |
| Oct          | 14.712   | 2.111  | 12.601  | 12,601                                     |
| Nov          | 31.233   | 3.348  | 27.885  | 27,885                                     |
| Dec          | 79.535   | 6.555  | 72.978  | 72,978                                     |
| Jan 1984     | 72.756   | 7.413  | 65.343  | 65,343                                     |
| Feb          | 48.091   | 4.788  | 43.303  | 43,303                                     |
| Mar          | 48.695   | 5.770  | 42.925  | 42,925                                     |
| Apr          | 29.361   | 2.959  | 26.402  | 26,402                                     |
| May          | 31.982   | 1.856  | 30.126  | 30,126                                     |
| Jun          | 18.528   | 0  | 18.528  | 18,528                                     |
| Jul          | 15.399   | 0  | 15.399  | 15,399                                     |
| Aug          | 13.475   | 0  | 13.475  | 13,475                                     |
| Sep          | 16.547   | 0.496  | 16.051  | 16,051                                     |
| Oct          | 21.285   | 1.698  | 19.587  | 19,587                                     |
| Nov          | 41.198   | 3.792  | 37.406  | 37,406                                     |
| Dec          | 53.313   | 4.945  | 48.368  | 48,368                                     |
| Jan 1985     | 66.712   | 7.045  | 59.667  | 59,667                                     |
| Feb          | 59.973   | 5.892  | 54.081  | 54,081                                     |
| Mar          | 51.425   | 4.518  | 46.907  | 46,907                                     |

\* 1,000 Btu = 1 lb.

Table 1.5

## FY 83 CONSUMPTION

| <u>Month</u> | <u>Electricity</u><br><u>10<sup>6</sup> Btu</u> | <u>Natural Gas</u><br><u>10<sup>6</sup> Btu</u> | <u>Steam</u><br><u>10<sup>6</sup> Btu</u> | <u>Total</u><br><u>10<sup>6</sup> Btu</u> |
|--------------|---|---|---|---|
| Nov 1982     | 30,512.64                                       | 253.21  | 39,563                                    | 70,328.85                                 |
| Dec 1982     | 28,062.72                                       | 190.53  | 39,761                                    | 68,014.25                                 |
| Jan 1983     | 34,131.84                                       | 159.50  | 39,255                                    | 73,546.34                                 |
| Feb 1983     | 31,057.06                                       | 294.21  | 29,541                                    | 60,892.27                                 |
| Mar 1983     | 31,057.06                                       | 208.98  | 37,385                                    | 68,651.04                                 |
| Apr 1983     | 31,057.06                                       | 303.11  | 46,641                                    | 78,001.17                                 |
| May 1983     | 28,870.08                                       | 303.11  | 26,211                                    | 55,384.19                                 |
| Jun 1983     | 36,386.88                                       | 274.14  | 18,411                                    | 55,072.02                                 |
| Jul 1983     | 23,162.88                                       | 144.75  | 12,298                                    | 35,605.63                                 |
| Aug 1983     | 29,760.96                                       | 106.30  | 11,057                                    | 40,924.26                                 |
| Sep 1983     | 28,953.60                                       | 116.19  | 12,163                                    | 41,232.79                                 |
| Oct 1983     | 27,979.20                                       | 159.39  | 12,601                                    | 40,739.59                                 |
| TOTAL        | 360,991.98                                      | 2,513.42  | 324,887                                   | 688,392.37                                |

### 1.3 Present Energy Consumption

#### 1.3.1 Introduction

Once the recorded historial energy consumption is analyzed, a base year, or current project energy consumption profile is developed. This is based on historical and A/E collected data. A profile is developed for each energy type as well as for the total energy consumption. The purpose of this "comparatory base" is for the evaluation of the proposed ECO's.

#### 1.3.2 Present Electrical Consumption

Electrical consumption at Building 4 is recorded by TACOM at meters 1, 6, 8, 13, 14 and 15. These meters correspond to substations 2, 4A, 4B, heat treat, 3 and 1, respectively. To estimate the present energy consumption at Building 4, it was necessary to simultaneously meter the nine transformers associated with the above mentioned substations (see Narrative Summary, Section 6.2.2.1). This was completed for a two-week period using nine Dranetz No. 808 power demand analyzers. A representative week (April 15, 1985 to April 21, 1985) is shown in Tables 6.12 through 6.19 of Narrative Summary, Section 6.2.2. These tables show the hourly kWH readings at each transformer. These readings were used to generate Table 1.6, a two-week listing of electrical consumption at Building 4. This data was utilized to generate a monthly electrical energy consumption estimate of 2,685.109 MWH per month. (See Narrative summary, Section 6.2.2 for more detailed analysis.)

Viewing Figure 6.1 of Section 6.1 of the Narrative Summary, it is obvious that the historical electrical profile is not a straight line. Localized peaks appear in

Table 1.6

# ELECTRICAL ENERGY PROFILE (MWH)

| SUBSTATION<br># | MONDAY<br>4/8/85 | TUESDAY<br>4/9/85 | WEDNESDAY<br>4/10/85 | THURSDAY<br>4/11/85 | FRIDAY<br>4/12/85 | SATURDAY<br>4/13/85 | SUNDAY<br>4/14/85 | MONDAY<br>4/15/85 | TUESDAY<br>4/16/85 | WEDNESDAY<br>4/17/85 | THURSDAY<br>4/18/85 | FRIDAY<br>4/19/85 | SATURDAY<br>4/20/85 | SUNDAY<br>4/21/85 | 1WEEK<br>TOTAL | ONEWEEK<br>AVERAGE | MONTHLY<br>ESTIMATE |
|-----------------|------------------|-------------------|----------------------|---------------------|-------------------|---------------------|-------------------|-------------------|--------------------|----------------------|---------------------|-------------------|---------------------|-------------------|----------------|--------------------|---------------------|
| 1A              | 11.730           | 11.790            | 11.820               | 11.940              | 11.970            | 11.330              | 11.100            | 12.000            | 12.110             | 11.920               | 12.150              | 11.940            | 10.870              | 10.490            | 163.240        | 81.620             |                     |
| 1B              | 4.837            | 4.855             | 4.882                | 4.814               | 4.951             | 4.740               | 4.704             | 4.984             | 5.025              | 5.037                | 5.250               | 5.494             | 5.303               | 5.312             | 70.196         | 35.098             | 505.389             |
| 2A              | 9.321            | 9.920             | 10.310               | 10.660              | 10.110            | 8.868               | 8.244             | 9.297             | 8.753              | 9.235                | 9.935               | 9.925             | 8.728               | 8.026             | 131.332        | 65.666             |                     |
| 2B              | 11.280           | 11.540            | 11.510               | 11.590              | 11.650            | 10.880              | 10.370            | 11.720            | 11.380             | 10.910               | 11.330              | 11.130            | 9.572               | 9.790             | 154.652        | 77.326             | 619.155             |
| 3A              | 9.401            | 10.140            | 10.250               | 9.805               | 9.472             | 9.015               | 7.724             | 10.380            | 10.200             | 10.780               | 11.070              | 11.190            | 10.040              | 9.576             | 139.043        | 69.522             |                     |
| 3B              | 10.950           | 11.330            | 11.270               | 11.220              | 11.210            | 10.450              | 10.020            | 10.350            | 10.710             | 11.200               | 10.700              | 11.250            | 10.250              | 9.949             | 150.859        | 75.430             | 627.630             |
| 4A              | 18.510           | 19.040            | 19.380               | 18.840              | 18.700            | 16.190              | 15.260            | 18.720            | 18.910             | 19.140               | 18.990              | 18.660            | 17.640              | 15.410            | 253.390        | 126.695            | 548.589             |
| 4B              | 12.000           | 11.620            | 12.460               | 12.050              | 11.450            | 8.970               | 6.521             | 11.650            | 11.590             | 12.300               | 12.020              | 12.330            | 10.000              | 8.977             | 153.938        | 76.969             | 333.276             |
| HEAT TREAT      | 1.891            | 1.583             | 1.840                | 1.856               | 1.767             | 1.448               | 1.452             | 1.880             | 1.738              | 2.257                | 1.472               | 1.492             | 1.453               | 1.456             | 23.585         | 11.793             | 51.062              |
| TOTAL           | 89.920           | 91.818            | 93.722               | 92.775              | 91.280            | 81.891              | 75.395            | 91.061            | 90.416             | 92.779               | 92.925              | 93.411            | 83.856              | 78.986            | 1240.235       | 620.118            | 2685.109            |

January and July. This may be explained by either weather conditions or production changes. Lacking concrete historical production data, the monthly estimation of 2,685.109 MWH per month is utilized to generate the annual profile shown in Figure 1.3.

#### 1.3.3 Present Natural Gas Consumption

The natural gas consumed at Building 4 is dependent on production as the natural gas is consumed in the heat treat area. Because of the lack of production data, the natural gas consumption in the heat treat area will be assumed to be the average consumption for the period September 1982 through March 1985. The present natural gas consumption is shown in Figure 1.4.

#### 1.3.4 Present Steam Consumption

Steam consumption at Building 4 consists of two components: 1) base steam, and 2) heating and ventilation steam.

Base steam consists of production steam use and boiler house use. Production steam is predominantly utilized in the heat/surface treatment area. Boiler house use includes regeneration, blowoff and compressed air generation. An accurate split between Building 4 production steam use and boiler house steam use cannot be obtained at this time because the boiler house utilization is not known. Because of this, the base steam for the period September 1982 to March 1985 is averaged to obtain a flat base steam consumption profile (see Figure 1.5). Once a positive metering strategy is implemented, base steam can be divided into its component parts. (See Narrative Summary, Section 6.1.4 for more detailed breakdown of steam consumption.)

Figure 1.3




Figure 1.4





Figure 1.5





Present heating and ventilation steam requirements are based on the results of the Trace V500 computer analysis (see Table 1.7). This monthly data was then combined with the estimated base steam to yield an annual steam load profile (Figure 1.5).

#### 1.3.5 Conclusions

Building 4 present energy consumption is shown in Figure 1.6, Figure 1.7 and Table 1.8. The energy types have been converted to source requirements using the following conversions:

|                                    |   |            |
|------------------------------------|---|------------|
| 1 kWH                              | = | 11,600 Btu |
| 1 cf                               | = | 1,031 Btu  |
| 1 lb. steam                        | = | 1,000 Btu  |
| % Coal for Steam Production        | = | 62.18%     |
| % Natural Gas for Steam Production | = | 37.82%     |
| Conversion and System Efficiency   | = | 52%        |

The present energy consumption profile will be utilized to compare the effectiveness of the proposed ECO's.

Table 1.7

BUILDING 4 HEATING AND VENTILATION LOAD

| <u>Month</u> | <u>10<sup>6</sup> lb. Steam</u> |
|--------------|---------------------------------|
| Jan          | 30.76                           |
| Feb          | 29.28                           |
| Mar          | 20.27                           |
| Apr          | 5.64                            |
| May          | 0.81                            |
| Jun          | 0                               |
| Jul          | 0                               |
| Aug          | 0                               |
| Sep          | 0.03                            |
| Oct          | 3.85                            |
| Nov          | 15.38                           |
| Dec          | 33.02                           |

Figure 1.6




Figure 1.7

# PROJECTED CURRENT ENERGY CONSUMPTION

TOTAL SOURCE ENERGY




Table 1.8

## DATP PROJECTED CURRENT ENERGY CONSUMPTION

|                  | J        | F        | M        | A        | M        | J        | J        | A        | S        | O        | N        | D        |
|------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| PROCESS          |          |          |          |          |          |          |          |          |          |          |          |          |
| GAS-CF           | 194680   | 194680   | 194680   | 194680   | 194680   | 194680   | 194680   | 194680   | 194680   | 194680   | 194680   | 194680   |
| GAS-BTU          | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  | 2.0E+08  |
| HV STEAM-LBS     | 30760000 | 29280000 | 20270000 | 5640000  | 810000   | 0        | 0        | 0        | 30000    | 3850000  | 15100000 | 33000000 |
| HV STEAM-BTU     | 3.1E+10  | 2.9E+10  | 2.0E+10  | 5.6E+09  | 8.1E+08  | 0        | 0        | 0        | 30000000 | 3.9E+09  | 1.5E+10  | 3.3E+10  |
| BASE STEAM-LBS   | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 | 17765516 |
| BASE STEAM-BTU   | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  |
| TOTAL STEAM-LBS  | 48526516 | 47045516 | 39035516 | 23405516 | 18575516 | 17765516 | 17765516 | 17765516 | 17795516 | 21615516 | 3345516  | 33785516 |
| TOTAL STEAM-BTU  | 4.9E+10  | 4.7E+10  | 3.8E+10  | 2.3E+10  | 1.9E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 1.8E+10  | 2.2E+10  | 3.3E+10  | 5.1E+10  |
| STEAM-SOURCE-BTU | 9.3E+10  | 9.0E+10  | 7.3E+10  | 4.5E+10  | 3.6E+10  | 3.4E+10  | 3.4E+10  | 3.4E+10  | 3.4E+10  | 4.2E+10  | 6.4E+10  | 8.8E+10  |
| STEAM-GAS-BTU    | 3.5E+10  | 3.4E+10  | 2.8E+10  | 1.7E+10  | 1.4E+10  | 1.3E+10  | 1.3E+10  | 1.3E+10  | 1.3E+10  | 1.6E+10  | 2.4E+10  | 3.7E+10  |
| STEAM-COAL-BTU   | 5.8E+10  | 5.6E+10  | 4.5E+10  | 2.8E+10  | 2.2E+10  | 2.1E+10  | 2.1E+10  | 2.1E+10  | 2.1E+10  | 2.6E+10  | 4.0E+10  | 5.1E+10  |
| ELECT-KWH        | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 | 2685.109 |
| ELECT-BTU        | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  | 9.2E+09  |
| ELECT-BTU-S      | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  | 3.1E+10  |
| GAS-TOTAL-BTU    | 3.5E+10  | 3.4E+10  | 2.8E+10  | 1.7E+10  | 1.4E+10  | 1.3E+10  | 1.3E+10  | 1.3E+10  | 1.3E+10  | 1.6E+10  | 2.4E+10  | 3.7E+10  |
| COAL COST (\$)   | 141634.1 | 137314.3 | 111016.3 | 68314.98 | 54217.39 | 51953.20 | 51853.20 | 51853.20 | 51940.76 | 63090.41 | 96743.67 | 148070.5 |
| ELECT. COST (\$) | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 | 158726.4 |
| N.GAS COST (\$)  | 175084.4 | 169774.7 | 137449.8 | 84962.30 | 67633.87 | 64727.87 | 64727.87 | 64727.87 | 63845.31 | 77550.19 | 118918.9 | 182001.7 |

DATAFILE \*\*CURRENT\*\*

#### 1.4 Production Profile

The historical production profile is not available to the A/E due to the sensitive nature of this information. After discussing this issue with General Dynamics and the Louisville Corps of Engineers, it was decided to use the production rate of 60 tanks per month as a historical average.

This information would be valuable in the determination of production energy consumption on a per tank basis. With this information, it would then be possible to predict the increase or decrease in production energy consumption due to changing production rates.

## 1.5 Pending and Prior Projects

The following is a brief description of pending and prior projects at Building 4, Detroit Arsenal Tank Plant, Warren, Michigan. (See Appendix B, Section C for current PS&ER Report, and Appendix A, Section D for prior ECO documentation.)

### 1.5.1 Building Envelope

#### 1.5.1.2 Roof

PS&ER Project 84-3 is described as Roof Minor Repair - Building 4. This project addresses roof penetrations identified in the Interim Report. PS&ER Project 86-2 is described as Major Roof Replacement. This project will result in a total R value of 20 for the roof. No further ECO will be developed in this area.

#### 1.5.1.3 Walls

The majority of the building vertical skin was single glazed, factory-type window units. The window units have been replaced with fiberglass and steel panels which have reduced both the conductive and infiltrative losses associated with single glazed window units. The total R value of the new wall section is 14\*. No further ECO will be developed in this area.

\* Source: Detroit Arsenal Facilities Energy Plan

#### 1.5.1.4 Doors

The doors and entryways at Building 4 have varied utilization rates. Three overhead doors utilize air locks

and one train door utilizes a strip-type door. All overhead doors have been fitted with door heaters under PS&ER Project 81-1.

#### 1.5.1.5 Windows

The windows at Building 4 were replaced at the time insulated wall panels were installed. These windows are aluminum framed, single-pane acrylic. The windows are located along the entire perimeter of the building with each window unit being approximately 2 feet 9 inches high by 4 feet wide.

#### 1.5.1.6 Monitors

Existing roof monitors were single glazed and did not have favorable sealing characteristics. PS&ER Projects 79-1, 79-2, 79-5 and 79-6 addressed the monitors. The monitors have been fitted with an insulated panel to obtain a total R value of 12 and gasketing for a more positive seal.

#### 1.5.2 Mechanical Systems

##### 1.5.2.1 Heating and Ventilating Systems

PS&ER Project 81-1 installed heating and ventilating units at Building 4, which included the door heaters at the overhead doors as well as the heating and ventilating units in the majority of the building.

##### 1.5.2.2 Exhaust Systems

PS&ER Project 83-2 included a new exhaust system in the heat/surface treatment area. As this design is not complete, further information is not available.



#### 1.5.2.3 Steam Distribution

Project Al-30-20, Contract No. DACA 45-80-C-0091 (GARD Analysis) included two ECO's which apply to Building 4 steam distribution system. Sub-Project B-1 recommended insulation on steam valves and piping at existing pressure reducing valve (PRV) stations. This project included the 45 PRV stations in the facility, of which 2 are in Building 4. Sub-Project B-1 also recommended the institution of a steam trap inspection program. These two projects have been instituted as an ongoing maintenance item by General Dynamics.

#### 1.5.3 Process Systems

Four ECO's were developed under Project Al-30-20, Contract No. DACA 45-80-C-0091 (GARD Analysis). These ECO's were aimed at the heat/surface treatment area and include:

- Treatment tank insulation.
- Treatment tank covers.
- Water shut off valve.
- Rinse water heat recovery.

It is the A/E's understanding that these ECO's have been considered in the design to be implemented under PS&ER Project 83-2.

#### 1.5.4 Electrical Systems

##### 1.5.4.1 Lighting

Project F-2, Contract No. DACA 45-80-C-0091, recommended the fitting of the fluorescent fixtures in the

general office area with time clocks in order to minimize lighting use during unoccupied hours. This is currently scheduled to be a function of the EMCS installed as PS&ER Project 81-2.

Lighting in the general production/work areas has been converted to high pressure sodium lighting under a prior project.

The study "Load Analysis for Building No. 4", AMC Project 4764565, 21 May 1976, resulted in the entire electrical distribution system of Building 4 to be rehabilitated under Contract No. DACA 45-77-C-0132, dated May 1977. The electrical consumption study, completed as part of Project A1-30-20, Contract No. DACA 45-80-C-0091 (GARD Analysis) dated September 1983, measured electrical consumption at each substation of Building 4 for a period of one week. The recommendations of this report were:

- Evaluation of the feasibility of either replacing transformer 4A with one of greater capacity, or shifting some loads currently served by substation 4A to a neighboring substation.
- The implementation of a second study to trace a low activity period electrical load (1,600 kW, 62 percent) to the "N" panel level and, if necessary, to the "D" panel level.

PS&ER Project 85-8 is described as Substation No. 4 Upgrade and PS&ER Project 85-2 is described as 110 Volt Electrical System - Building 4.

#### 1.5.5 Energy Management and Control System

PS&ER Project 81-2 is described as "EMCS". This project is currently in the installation phase.

#### 1.5.6 Interior Spaces

Proposed modifications to interior spaces are:

- General Office Area Renovation, PS&ER Project 88-7
- Gage Lab Facility, PS&ER Project 85-6a
- Material Lab Facility, PS&ER Project 85-4.

#### 1.5.7 Energy Production

An analysis of Building 5 (boiler house) is not included under this project. Since Building 4 is a primary user of energy, it was thought appropriate to mention the cogeneration feasibility study generated from Project A1-30-20, Contract No. DACA 45-80-C-0091 for reference only. The study concluded that the installation of a cogeneration system is feasible and meets ECIP criteria.

## 1.6 Energy Conservation Analysis

### 1.6.1 Introduction

Starting from the entrance interview to the present, SH&G has proceeded with the project as outlined in Methods and Approaches of the Narrative Summary, Section 2.

The first task was to obtain the basic information needed for the project. The data and information to be provided by the Corps of Engineers and TACOM has been received and incorporated into the project. Part of the data to be provided by General Dynamics was not available. Due to the lack of this information, some aspects of this analysis were not developed. Information obtained by SH&G was developed into survey sheets and zone information sheets (see Appendix B, Sections E and F). From this information, the following ECO's were considered.

- ECO No. 1 - Welding Filter Installation
- ECO No. 2 - Vehicle Adjust Heat Recovery Installation
- ECO No. 3 - Destratification of Plant Air
- ECO No. 4 - Air Curtains
- ECO No. 5 - Storm Sash in Office Area
- ECO No. 6 - Economizer for Office AC Units
- ECO No. 7 - Replace DX Units with Rooftop Units
- ECO No. 8 - Heat Recovery from Wash Booths
- ECO No. 9 - Treatment Tank Condensate Heat Recovery
- ECO No. 10 - Heat/Surface Treatment Area Exhaust Heat Recovery
- ECO No. P1 - Treatment Tank Insulation
- ECO No. P2 - Rinse Water Shutoff Valve
- ECO No. P3 - Rinse Water Heat Recovery
- ECO No. P4 - Treatment Tank Covers

ECO No's. 1 through 10 were initially investigated and ECO No's. P1 through P4 were re-evaluated as they were prior projects developed under Contract No. DACA45-80-C-0091 (GARD Analysis).

During the interim review session, the A/E was advised to take no further action on ECO No's 8 through 10. These ECO's will be addressed in current renovation projects.

In addition to the above investigated ECO's, the items of Annex A of the Scope of Work were commented on as a result of a prior review meeting. This can be found in the Narrative Summary, Section 5.

#### 1.6.2 ECO's Investigated

The following is a brief description of the ECO's, followed by a summary of the life-cycle cost analysis. See Table 1.9 for Summary of Investigated ECO's.

##### 1.6.2.1 ECO No. 1 - Welding Filter Installation

Presently, the buildup of welding fumes in the turret and hull welding areas is being prevented by the relief of large quantities of warm plant air through open roof monitor sections. During the heating season, a significant energy loss is associated with this dumping of heated plant air.

In order to reclaim this energy, the installation of high efficiency media type filters is proposed. These units would allow the warm, previously exhausted air to be recycled for ventilation purposes, and would significantly reduce the amount of outdoor air which would require heating. In total, six 40,000 CFM units are proposed in order to take warm welding fume laden air from high in the bay,

Table 1.9

## SUMMARY OF INVESTIGATED ECO'S

| ECO<br>No. | ECO<br>Description                              | SIR   | Net Annual<br>Energy<br>Savings<br>(MBtu) | CWE<br>(\$) | First Year<br>Savings<br>(\$) | Total Net<br>Discounted<br>Savings<br>(\$) |
|------------|---|-------|---|-------------|-------------------------------|--|
| P2         | Rinse Water<br>Shut Off Valve                   | 79.46 | 1,967.00                                  | 1,908.17    | 9,058.52                      | 142,992.82                                 |
| P3         | Rinse Water<br>Heat Recovery                    | 44.68 | 2,180.68                                  | 3,260.40    | 8,227.41                      | 137,376.54                                 |
| P1         | Treatment Tank<br>Insulation                    | 9.41  | 4,807.50                                  | 34,121.00   | 18,138.06                     | 302,859.23                                 |
| 3          | Destratification<br>of Plant Air                | 5.99  | 22,934.08                                 | 176,061.60  | 86,527.21                     | 994,700.10                                 |
| P4         | Treatment Tank<br>Covers                        | 5.17  | 1,696.40                                  | 15,081.44   | 6,400.30                      | 73,576.61                                  |
| 1          | Welding Filter<br>Installation                  | 3.49  | 35,029.40                                 | 612,849.24  | 104,744.00                    | 2,016,082.39                               |
| 4          | Air Curtains                                    | 2.69  | 4,826.91                                  | 82,260.95   | 18,039.55                     | 208,957.27                                 |
| 2          | Vehicle Adjust<br>Heat Recovery<br>Installation | 2.62  | 17,342.56                                 | 427,655.80  | 56,155.92                     | 1,057,704.23                               |
| 5          | Storm Sash in<br>Office Area                    | 1.14  | 491.55                                    | 28,868.12   | 1,866.04                      | 30,907.97                                  |
| 7          | Economizer for<br>Office A/C Units              | 0.07  | 905.26                                    | 667,044.40  | 4,613.20                      | 42,026.30                                  |
| 6          | Replace DX Units<br>with Rooftop<br>Unit        | 0.26  | 1,868.07                                  | 471,313.39  | 33,740.15                     | 307,372.81                                 |

filter the air, and send it back down to the work area. Adequate filtration of this type would allow the monitors to remain closed during the heating season, thus eliminating the large energy wastage associated with the dumping of the heated plant air. The resultant energy savings were estimated using the Trace computer energy estimating program.

**ECO No. 1**

Analysis Date: April 10, 1985

|                                |                       |
|--------------------------------|-----------------------|
| Construction Cost              | \$586,458.60          |
| SIOH (4.5%)                    | \$ 26,390.64          |
| Current Working Estimate (CWE) | \$612,849.24          |
| Annual Energy Savings          |                       |
| Natural Gas                    | 15,476.85 MBtu/yr.    |
| Coal                           | 25,445.55 MBtu/yr.    |
| Electricity                    | -5,893.00 MBtu/yr.    |
| TOTAL                          | 35,029.40 MBtu/yr.    |
| Annual Dollar Savings          |                       |
| Natural Gas                    | \$ 76,347.30/yr.      |
| Coal                           | 62,112.59/yr.         |
| Electricity                    | <u>-30,030.73/yr.</u> |
| SUBTOTAL                       | \$108,429.16/yr.      |
| Annual Recurring               | <u>-3,685.16/yr.</u>  |
| TOTAL                          | \$104,744.00/yr.      |
| SIR                            | 3.49                  |

1.6.2.2 ECO No. 2 - Vehicle Adjust Heat Recovery Installation

At present, air is being exhausted through roof monitors in the vehicle adjust areas in order to prevent the buildup of tank vehicle exhaust fumes to hazardous levels. Additionally, since the exhaust through the monitors is uncontrolled, the present exhaust rate is excessive.

The addition of run-around coil type heat recovery units is proposed in these areas in order to bring the exhaust rates down to a controlled, reasonable level and to recover a portion of the heat contained in the air before it is exhausted. Two heat recovery coil units will be incorporated with existing make-up air units and two additional combination heat recovery make-up air units will be installed in order to serve the vehicle adjust areas in K Bay and L Bay, respectively. By recovering some of the heat energy in exhausted air and using this energy to temper incoming outdoor air, steam consumption and energy costs can be significantly reduced. The resultant energy savings were estimated using the Trace computer energy estimating program.

**ECO No. 2**

Analysis Date: April 10, 1985

|                                |                       |
|--------------------------------|-----------------------|
| Construction Cost              | \$409,240.00          |
| SIOH (4.5%)                    | \$ 18,415.80          |
| Current Working Estimate (CWE) | \$427,655.80          |
| Annual Energy Savings          |                       |
| Natural Gas                    | 7,826.68 MBtu/yr.     |
| Coal                           | 12,867.88 MBtu/yr.    |
| Electricity                    | -3,352.00 MBtu/yr.    |
| TOTAL                          | 17,342.56 MBtu/yr.    |
| Annual Dollar Savings          |                       |
| Natural Gas                    | \$ 38,609.01/yr.      |
| Coal                           | 31,410.50/yr.         |
| Electricity                    | <u>-17,081.79/yr.</u> |
| SUBTOTAL                       | \$ 52,937.72/yr.      |
| Annual Recurring               | <u>3,218.20/yr.</u>   |
| TOTAL                          | \$ 56,155.92/yr.      |
| SIR                            | 2.62                  |



#### 1.6.2.3 ECO No. 3 - Destratification of Plant Air

At present, HV units 1 through 27 are fitted with diffusers having a horizontal throw distribution pattern. Because of this design, heated air from the HV units is being delivered to and remains in the truss space. This delivery of air at truss level combined with warm air's natural tendency to rise, creates a temperature gradient in the space, with the work place down at floor level being the coldest, and the truss space, which is unoccupied, being the warmest. This leads to both greater conductive heat loss through the roofing material and greater energy loss associated with roof exfiltration losses. This stratification is to be reduced by the installation of long vertical throw diffusers which will help bring the warm air from the HV units in the truss space down to the work place. This will help to create a more uniform temperature distribution from floor to ceiling and will reduce the energy wastage associated with stratification.

The resultant energy savings were estimated using the Trace computer energy estimating program.

#### ECO No. 3

Analysis Date: April 10, 1985

|                                |                    |
|--------------------------------|--------------------|
| Construction Cost              | \$168,480.00       |
| SIOH (4.5%)                    | \$ 7,581.60        |
| Current Working Estimate (CWE) | \$176,061.60       |
| Annual Energy Savings          |                    |
| Natural Gas                    | 8,673.67 MBtu/yr.  |
| Coal                           | 14,260.41 MBtu/yr. |
| Electricity                    | 0                  |
| TOTAL                          | 22,934.08 MBtu/yr. |

|                       |                  |
|-----------------------|------------------|
| Annual Dollar Savings |                  |
| Natural Gas           | \$ 42,787.21/yr. |
| Coal                  | 34,809.66/yr.    |
| Electricity           | 0                |
| SUBTOTAL              | \$ 77,596.87/yr. |
| Annual Recurring      | 8,930.34/yr.     |
| TOTAL                 | \$ 82,527.21/yr. |
| SIR                   | 5.99             |

1.6.2.4 Interactive Effects of ECO No. 1, ECO No. 2 and ECO No. 3 - Welding Filter Installation, Vehicle Adjust Heat Recovery and Destratification

Since ECO No. 1, ECO No. 2 and ECO No. 3 have interactive effects on one another, it is necessary to determine the combined effect of implementing all ECO's simultaneously. Therefore, the Trace computer model was used to estimate the combined energy savings assuming all three ECO's were implemented.

ECO No's. 1, 2 and 3  
Analysis Date: April 10, 1985

|                                |                    |
|--------------------------------|--------------------|
| Construction Cost              | \$1,164,178.60     |
| SIOH (4.5%)                    | \$ 52,388.04       |
| Current Working Estimate (CWE) | \$1,216,566.64     |
| Annual Energy Savings          |                    |
| Natural Gas                    | 31,175.23 MBtu/yr. |
| Coal                           | 52,255.00 MBtu/yr. |
| Electricity                    | -9,245.00 MBtu/yr. |
| TOTAL                          | 73,185.23 MBtu/yr. |
| Annual Dollar Savings          |                    |
| Natural Gas                    | \$ 153,787.41/yr.  |
| Coal                           | 125,113.46/yr.     |
| Electricity                    | -47,112.52/yr.     |
| SUBTOTAL                       | \$ 231,788.34/yr.  |
| Annual Recurring               | 7,637.76/yr.       |
| TOTAL                          | \$ 239,426.10/yr.  |
| SIR                            | 3.82               |

#### 1.6.2.5 ECO No. 4 - Air Curtains

There are three energy conservation strategies which could be utilized at an entryway. They are airlocks, strip doors, and air curtains.

Airlocks require a small energy input, but are easily bypassed. It takes time for a tank to go through one door, wait for it to close, then wait for the next door to open. Because of this inconvenience, air locks are bypassed. During the A/E's visit to the facility, airlocks were never used as intended.

Strip doors lack a positive seal and are easy to destroy. Door No. 37 at Building 4 illustrates how strip doors are cut to keep from interfering with traffic flows.

Air curtains utilize a controlled stream of air aimed across an open door to create an air seal. They are effective in reducing infiltration which occurs when the door is open. Air curtains require an energy input, but are not as frequently bypassed as they do not slow the flow of traffic.

#### **ECO No. 4**

Analysis Date: April 10, 1985

|                                |                   |
|--------------------------------|-------------------|
| Construction Cost              | \$78,910.00       |
| SIOH (4.5%)                    | \$ 3,350.95       |
| Current Working Estimate (CWE) | \$82,260.95       |
| Annual Energy Savings          |                   |
| Natural Gas                    | 1,874.63 MBtu/yr. |
| Coal                           | 3,082.08 MBtu/yr. |
| Electricity                    | -129.80 MBtu/yr.  |
| TOTAL                          | 4,826.91 MBtu/yr. |

|                       |                     |
|-----------------------|---------------------|
| Annual Dollar Savings |                     |
| Natural Gas           | \$ 9,247.55/yr.     |
| Coal                  | 7,523.36/yr.        |
| Electricity           | <u>-661.46/yr.</u>  |
| SUBTOTAL              | \$16,109.45/yr.     |
| Annual Recurring      | <u>2,573.47/yr.</u> |
| TOTAL                 | \$18,039.55/yr.     |
| SIR                   | 3.61                |

#### 1.6.2.6 ECO No. 5 - Storm Sash on Office Windows

The general office area along the north perimeter presently incorporates a single glazed window system. The majority of these windows are operable. The single glazed windows can be fit with a storm sash. This will result in a savings due to decreased conduction and infiltration losses associated with the present system.

ECO No. 5  
Analysis Date April 10, 1985

|                                |                   |
|--------------------------------|-------------------|
| Construction Cost              | \$27,625.00       |
| SIOH (4.5%)                    | \$ 1,243.12       |
| Current Working Estimate (CWE) | \$28,868.12       |
| Annual Energy Savings          |                   |
| Natural Gas                    | 182.59 MBtu/yr.   |
| Coal                           | 300.20 MBtu/yr.   |
| Electricity                    | 8.76 MBtu/yr.     |
| TOTAL                          | 491.55 MBtu/yr.   |
| Annual Dollar Savings          |                   |
| Natural Gas                    | \$ 900.63/yr.     |
| Coal                           | 732.79/yr.        |
| Electricity                    | <u>44.64/yr.</u>  |
| SUBTOTAL                       | \$ 1,678.05/yr.   |
| Annual Recurring               | <u>187.99/yr.</u> |
| TOTAL                          | \$ 1,866.14/yr.   |
| SIR                            | 1.14              |

#### 1.6.2.7 ECO No. 6 - Economizer for Office A/C Units

The general office area is served by many different units. The majority of these units are Chrysler Air-Temp 10-ton units. The primary function of these units is to remove the internal heat gain of the space. These units are 100 percent recirculation.

These units can be modified to allow for 100 percent outside air when the conditions are correct, or a portion of outdoor air will be mixed with return air to provide for proper discharge conditions. This will require the addition of economizer controls and ductwork from the units to an outside air source.

#### **ECO No. 6**

Analysis Date: April 10, 1985

|                                |                 |
|--------------------------------|-----------------|
| Construction Cost              | \$638,320.00    |
| SIOH (4.5%)                    | \$ 28,724.40    |
| Current Working Estimate (CWE) | \$667,044.40    |
| Annual Energy Savings          |                 |
| Natural Gas                    | 0               |
| Coal                           | 0               |
| Electricity                    | 905.26 MBtu/yr  |
| TOTAL                          | 905.26 MBtu/yr. |
| Annual Dollar Savings          |                 |
| Natural Gas                    | 0               |
| Coal                           | 0               |
| Electricity                    | \$ 4,613.20/yr. |
| SUBTOTAL                       | \$ 4,613.20/yr. |
| Annual Recurring               | 0               |
| TOTAL                          | \$ 4,613.20/yr. |
| SIR                            | 0.07            |

#### 1.6.2.8 ECO No. 7 - Replace DX Units with Rooftop Units

The general office area is served by many different units. The primary function of these units is to remove the internal heat gain of the space. These units are 100 percent recirculation.

These units can be eliminated and replaced with rooftop units. As agreed in the interim review, the A/E is to perform a basic evaluation of this proposed ECO.

##### **ECO No. 7**

Analysis Date: April 10, 1985

|                                |                      |
|--------------------------------|----------------------|
| Construction Cost              | \$451,071.60         |
| SIOH (4.5%)                    | \$ 20,295.79         |
| Current Working Estimate (CWE) | \$471,313.39         |
| Annual Energy Savings          |                      |
| Natural Gas                    | 0                    |
| Coal                           | 0                    |
| Electricity                    | 1,868.07 MBtu/yr.    |
| TOTAL                          | 1,868.07 MBtu/yr.    |
| Annual Dollar Savings          |                      |
| Natural Gas                    | 0                    |
| Coal                           | 0                    |
| Electricity                    | \$ 9,519.68/yr.      |
| SUBTOTAL                       | \$ 9,519.68/yr.      |
| Annual Recurring               | <u>24,220.47/yr.</u> |
| TOTAL                          | \$ 33,740.15/yr.     |
| SIR                            | 0.26                 |

#### 1.6.2.9 ECO No. Pl - Treatment Tank Insulation

The surface treatment area prepares the surface of components which require painting or plating. The renovated surface treatment area will contain 7 tanks which will

maintain a temperature above ambient. These tanks remain at their operating temperature 24 hours per day.

Treatment tanks primarily lose energy through conduction and evaporation. Conduction through tank sides and bottom can be the most easily controlled of the two means of heat loss. The insulation should be protected by a coating which is resistant to the chemicals utilized in this area and should offer good resistance to impact.

**ECO No. P1**

Analysis Date: April 10, 1985

|                                |                     |
|--------------------------------|---------------------|
| Construction Cost              | \$32,652.00         |
| SIOH (4.5%)                    | \$ 1,469.00         |
| Current Working Estimate (CWE) | \$34,121.00         |
| Annual Energy Savings          |                     |
| Natural Gas                    | 1,818.20 MBtu/yr.   |
| Coal                           | 2,989.50 MBtu/yr.   |
| Electricity                    | 0                   |
| TOTAL                          | 4,807.70 MBtu/yr.   |
| Annual Dollar Savings          |                     |
| Natural Gas                    | \$ 8,969.18/yr.     |
| Coal                           | 7,297.37/yr.        |
| Electricity                    | 0                   |
| SUBTOTAL                       | \$16,266.55/yr.     |
| Annual Recurring               | <u>1,872.00/yr.</u> |
| TOTAL                          | \$18,188.06/yr.     |
| SIR                            | 9.41                |

1.6.2.10 ECO No. P2 - Treatment Tank Water Shutoff Valve

The hot water rinse tank is continually receiving fresh water. The fresh water must be raised to the tank operating temperature, while water already at the tank

operating temperature is being discharged. This is a continually occurring process, even when the tank is not in use.

A water shutoff valve should be integrated with the water supply line to modulate the supply of fresh water to the tank during periods of predicted inactivity. This will eliminate some of the unnecessary water changes and save the associated energy required to raise the fresh water to the tanks operating temperature. The shutoff valve should be integrated with either a timer or with the proposed EMCS (see Narrative Summary, Section 3).

To eliminate problems commonly associated with time clocks, it is the A/E's recommendation that the water shutoff valve be integrated with the proposed EMCS.

**ECO No. P2**

Analysis Date: April 10, 1985

|                                |                     |
|--------------------------------|---------------------|
| Construction Cost              | \$1,826.00          |
| SIOH (4.5%)                    | \$ 82.17            |
| Current Working Estimate (CWE) | \$1,908.17          |
| Annual Energy Savings          |                     |
| Natural Gas                    | 744.00 MBtu/yr.     |
| Coal                           | 1,223.00 MBtu/yr.   |
| Electricity                    | 0                   |
| TOTAL                          | 1,967.00 MBtu/yr.   |
| Annual Dollar Savings          |                     |
| Natural Gas                    | \$3,670.15/yr.      |
| Coal                           | 2,985.34/yr.        |
| Electricity                    | 0                   |
| SUBTOTAL                       | \$6,655.50/yr.      |
| Annual Recurring               | <u>2,403.02/yr.</u> |
| TOTAL                          | \$9,058.52/yr.      |
| SIR                            | 79.46               |



1.6.2.11 ECO No. P3 - Hot Water Rinse Heat Recovery

The hot water rinse tank is continually receiving fresh water. This fresh water must be raised to the tank operating temperature, while water already at the tank operating temperature is being discharged. Presently, this is a continually occurring process.

A tube-shell heat exchanger can be integrated with the supply and discharge lines to reclaim a portion of the energy required to raise the 55°F entering water to 160°F.

**ECO No. P3**

Analysis Date: April 10, 1985

|                                |                   |
|--------------------------------|-------------------|
| Construction Cost              | \$3,120.00        |
| SIOH (4.5%)                    | \$ 140.40         |
| Current Working Estimate (CWE) | \$3,260.40        |
| Annual Energy Savings          |                   |
| Natural Gas                    | 824.73 MBtu/yr.   |
| Coal                           | 1,355.95 MBtu/yr. |
| Electricity                    | 0                 |
| TOTAL                          | 2,180.68 MBtu/yr. |
| Annual Dollar Savings          |                   |
| Natural Gas                    | \$4,068.39/yr.    |
| Coal                           | 3,309.87/yr.      |
| Electricity                    | 0                 |
| SUBTOTAL                       | \$7,378.27/yr.    |
| Annual Recurring               | 849.14/yr.        |
| TOTAL                          | \$8,227.41/yr.    |
| SIR                            | 44.68             |

1.6.2.12 ECO No. P2 and ECO No. P3 - Water Shutoff Valve with Rinse Heat Recovery - Synergistic Effects

If both P2 (water shutoff valve) and P3 (rinse water heat recovery) are implemented, the savings are not additive. These ECO's affect the quantity and quality of the rinse water. Consequently, these ECO's are evaluated together.

**ECO No's. P2 and P3**

Analysis Date: April 10, 1985

|                                |                   |
|--------------------------------|-------------------|
| Construction Cost              | \$ 4,946.00       |
| SIOH (4.5%)                    | \$ 222.57         |
| Current Working Estimate (CWE) | \$ 5,168.57       |
| Annual Energy Savings          |                   |
| Natural Gas                    | 1,391.73 MBtu/yr. |
| Coal                           | 2,288.15 MBtu/yr. |
| Electricity                    | 0                 |
| TOTAL                          | 3,679.88 MBtu/yr. |
| Annual Dollar Savings          |                   |
| Natural Gas                    | \$ 6,865.40/yr.   |
| Coal                           | 5,585.37/yr.      |
| Electricity                    | 0                 |
| SUBTOTAL                       | \$12,450.78/yr.   |
| Annual Recurring               | 3,069.92/yr.      |
| TOTAL                          | \$15,520.70/yr.   |
| SIR                            | 51.47             |

1.6.2.13 ECO No. P4 - Treatment Tank Covers

The surface treatment area prepares the surface of the components requiring painting or plating. The renovated surface treatment area will contain 7 tanks which will be

significantly above the ambient temperature. An additional tank will be near ambient.

Treatment tanks primarily lose energy through conduction and evaporation. Evaporation is further accelerated at higher tank temperatures and with air movement across the exposed surface. Tank covers can be installed to reduce the evaporative heat loss of these treatment tanks.

Three types of covers were analyzed in the prior study. They were passive, motorized and manual (see Narrative Summary, Section 3 for discussion of the types). It is the A/E's recommendation that manual covers be utilized.

**ECO No. P4**

Analysis Date: April 10, 1985

|                                |                   |
|--------------------------------|-------------------|
| Construction Cost              | \$14,432.00       |
| SIOH (4.5%)                    | \$ 649.44         |
| Current Working Estimate (CWE) | \$15,081.44       |
| Annual Energy Savings          |                   |
| Natural Gas                    | 641.58 MBtu/yr.   |
| Coal                           | 1,054.82 MBtu/yr. |
| Electricity                    | 0                 |
| TOTAL                          | 1,696.40 MBtu/yr. |
| Annual Dollar Savings          |                   |
| Natural Gas                    | \$ 3,164.91/yr.   |
| Coal                           | 2,574.82/yr.      |
| Electricity                    | 0                 |
| SUBTOTAL                       | \$ 5,739.73/yr.   |
| Annual Recurring               | <u>660.57/yr.</u> |
| TOTAL                          | \$ 6,400.30/yr.   |
| SIR                            | 5.17              |

### 1.6.3 ECO's Recommended

Of the investigated ECO's, the following are recommended for implementation:

- ECO No. 1 - Welding Filter Installation
- ECO No. 2 - Vehicle Adjust Heat Recovery
- ECO No. 3 - Destratification of Plant Air
- ECO No. 4 - Air Curtains
- ECO No. 5 - Storm Sash in Office Area
- ECO No. P1 - Treatment Tank Insulation
- ECO No. P2 - Rinse Water Shutoff Valve
- ECO No. P3 - Rinse Water Heat Recovery
- ECO No. P4 - Treatment Tank covers

See Tables 1.10 and Table 1.11 for Summary of Recommended ECO's and Figure 1.8 through Figure 1.13 for graphic presentation of the energy reduction of the recommended ECO's.

Table 1.10

## SUMMARY OF RECOMMENDED ECO'S

| ECO<br>No. | ECO<br>Description                              | SIR   | Net Annual<br>Energy<br>Saving<br>(MBtu) | CWE<br>(\$) | First Year<br>Savings<br>(\$) | Total Net<br>Discounted<br>Savings<br>(\$) | Payback |
|------------|---|-------|--|-------------|-------------------------------|--|---------|
| P2         | Rinse Water<br>Shut Off Valve                   | 79.46 | 1,967.00                                 | 1,908.17    | 9,058.52                      | 142,992.82                                 | 12      |
| P3         | Rinse Water<br>Heat Recovery                    | 44.68 | 2,180.68                                 | 3,260.40    | 8,227.41                      | 137,376.54                                 | 14      |
| P1         | Treatment Tank<br>Insulation                    | 9.41  | 4,807.50                                 | 34,121.00   | 18,138.06                     | 302,859.23                                 | 19      |
| 3          | Destratification<br>of Plant Air                | 5.99  | 22,934.08                                | 176,061.60  | 86,527.21                     | 994,700.10                                 | 20      |
| P4         | Treatment Tank<br>Covers                        | 5.17  | 1,696.40                                 | 15,081.44   | 6,400.30                      | 73,576.61                                  | 24      |
| 1          | Welding Filter<br>Installation                  | 3.49  | 35,029.40                                | 612,849.24  | 104,744.00                    | 2,016,082.39                               | 59      |
| 4          | Air Curtains                                    | 2.69  | 4,826.91                                 | 82,260.95   | 18,039.55                     | 208,957.27                                 | 46      |
| 2          | Vehicle Adjust<br>Heat Recovery<br>Installation | 2.62  | 17,342.56                                | 427,655.80  | 56,155.92                     | 1,057,704.23                               | 76      |
| 5          | Storm Sash in<br>Office Area                    | 1.14  | 491.55                                   | 28,868.12   | 1,866.04                      | 30,907.97                                  | 15.5    |

Table 1.11

SYNERGISTIC EFFECTS OF RECOMMENDED ECO'S

| <u>ECO's</u> | <u>SIR</u> | Net Annual<br>Energy<br>Savings<br>(MBtu) | CWE<br>(\$)  | First Year<br>Savings<br>(\$) | Total Net<br>Discounted<br>Savings<br>(\$) |
|--------------|------------|---|--------------|-------------------------------|--|
| P2, P3       | 51.47      | 3,679.88                                  | 5,168.57     | 15,520.70                     | 20,893.21                                  |
| 1, 2, 3      | 3.82       | 73,185.23                                 | 1,216,566.64 | 239,426.10                    | 4,384,974.68                               |

Figure 1.8




Figure 1.9






Figure 1.10

# TOTAL ENERGY REDUCTION

ECO 5




Figure 1.11




Figure 1.12





Figure 1.13



## 1.7 Energy and Cost Savings

### 1.7.1 Introduction

The following ECO's have been recommended for implementation at Building 4:

|            |   |                               |
|------------|---|-------------------------------|
| ECO No. 1  | - | Welding Filter Installation   |
| ECO No. 2  | - | Vehicle Adjust Heat Recovery  |
| ECO No. 3  | - | Destratification of Plant Air |
| ECO No. 4  | - | Air Curtains                  |
| ECO No. 5  | - | Storm Sash in Office Area     |
| ECO No. P1 | - | Treatment Tank Insulation     |
| ECO No. P2 | - | Rinse Water shutoff Valve     |
| ECO No. P3 | - | Rinse Water Heat Recovery     |
| ECO No. P4 | - | Treatment Tank Covers         |

The implementation of the above ECO's will yeild the following energy and cost savings.

### 1.7.2 Electrical Consumption

The electrical consumption at Building 4 will increase after the implementation of the recommended ECO's. Table 1.12 summarizes the change in electrical consumption per ECO. This data is then utilized with information from Table 1.8 of Section 1.3 of the Executive Summary to generate Table 1.13. Using the totals in Table 1.13, the existing electrical energy cost is \$1,904,717.50 per year, and the proposed electrical energy cost is \$1,952,446.69 per year. This is a 2.5 percent increase in electrical consumption. See Figure 1.14 for existing versus proposed electrical consumption.

Table 1.12

**CHANGE IN ELECTRICAL CONSUMPTION**  
(10<sup>6</sup> Btu)

|      | <u>ECO</u><br><u>1, 2 &amp; 3</u> | <u>ECO</u><br><u>4</u> | <u>ECO</u><br><u>5</u> | <u>ECO</u><br><u>P1</u> | <u>ECO</u><br><u>P2, P3</u> | <u>ECO</u><br><u>P4</u> | <u>Total</u>    |
|------|-----------------------------------|------------------------|------------------------|-------------------------|-----------------------------|-------------------------|-----------------|
| Jan  | 1,394.96                          | 27.86                  | 0                      | 0                       | 0                           | 0                       | 1,422.81        |
| Feb  | 1,324.49                          | 24.13                  | 0                      | 0                       | 0                           | 0                       | 1,348.62        |
| Mar  | 1,430.19                          | 19.86                  | 0                      | 0                       | 0                           | 0                       | 1,450.05        |
| Apr  | 1,084.46                          | 9.36                   | -0.061                 | 0                       | 0                           | 0                       | 1,093.77        |
| May  | 716.71                            | 2.99                   | -0.438                 | 0                       | 0                           | 0                       | 719.26          |
| June | 0                                 | 0.21                   | -2.015                 | 0                       | 0                           | 0                       | -1.81           |
| Jul  | 0                                 | 0                      | -3.013                 | 0                       | 0                           | 0                       | -3.01           |
| Aug  | 0                                 | 0.10                   | -2.348                 | 0                       | 0                           | 0                       | -2.25           |
| Sep  | 19.82                             | 0.81                   | -0.788                 | 0                       | 0                           | 0                       | 19.84           |
| Oct  | 484.46                            | 5.18                   | -0.096                 | 0                       | 0                           | 0                       | 489.54          |
| Nov  | 1,394.96                          | 14.76                  | 0                      | 0                       | 0                           | 0                       | 1,409.71        |
| Dec  | 1,394.96                          | 24.52                  | 0                      | 0                       | 0                           | 0                       | <u>1,419.48</u> |
|      |                                   |                        |                        | TOTAL                   |                             |                         | 9,366.01        |

Table 1.13


**TOTAL ELECTRICAL CONSUMPTION**  
(Btu)

|       | <u>Existing</u>              | <u>Proposed</u>              |
|-------|------------------------------|------------------------------|
| Jan   | 31,147,264,400               | 32,570,074,400               |
| Feb   | 31,147,264,400               | 32,495,884,400               |
| Mar   | 31,147,264,400               | 32,597,314,400               |
| Apr   | 31,147,264,400               | 32,241,034,400               |
| May   | 31,147,264,400               | 31,866,524,400               |
| Jun   | 31,147,264,400               | 31,145,454,400               |
| Jul   | 31,147,264,400               | 31,144,254,400               |
| Aug   | 31,147,264,400               | 31,145,014,400               |
| Sep   | 31,147,264,400               | 31,167,104,400               |
| Oct   | 31,147,264,400               | 31,636,804,400               |
| Nov   | 31,147,264,400               | 32,556,974,400               |
| Dec   | <u>31,147,264,400</u>        | <u>32,566,744,400</u>        |
| TOTAL | 373,767.17 x 10 <sup>6</sup> | 383,133.18 x 10 <sup>6</sup> |

Figure 1.14

# TOTAL ELECTRICAL CONSUMPTION

ALL PROPOSED ECO'S





### 1.7.3 Natural Gas Consumption

The natural gas consumption at Building 4 will decrease after the implementation of the recommended ECO's. Table 1.14 summarizes the change in natural gas consumption per ECO. This data is then utilized with information from Table 1.8 of Section 1.3 of the Executive Summary to generate Table 1.15. Using the totals in Table 1.15, the existing natural gas cost is \$1,271,602.69 per year and the proposed natural gas cost is \$1,087,32.55 per year. This is a 14.5 percent decrease in natural gas consumption. See Figure 1.15 for existing versus proposed natural gas consumption.

### 1.7.4 Coal Consumption

The coal consumption at Building 4 will decrease after the implementation of the recommended ECO's. Table 1.16 summarizes the change in coal consumption per ECO. This data is then utilized with information from Table 1.8 of Section 1.3 of the Executive Summary to generate Table 1.17. Using the totals in Table 1.17, the existing coal cost is \$1,028,062.30 per year and the proposed coal cost is \$879,221.01 per year. This is a 14.5 percent decrease in coal consumption. See Figure 1.16 for existing versus proposed coal consumption.

### 1.7.5 Conclusions

The total energy consumption at Building 4 will decrease after the implementation of all recommended ECO's. Table 1.18 summarizes the monthly change in energy consumption by energy source. This translates into the following energy cost savings:

Table 1.14

**CHANGE IN NATURAL GAS CONSUMPTION**  
(10<sup>6</sup> Btu)

|     | <u>ECO</u><br><u>1, 2 &amp; 3</u> | <u>ECO</u><br><u>4</u> | <u>ECO</u><br><u>5</u> | <u>ECO</u><br><u>P1</u> | <u>ECO</u><br><u>P2, P3</u> | <u>ECO</u><br><u>P4</u> | <u>Total</u>    |
|-----|-----------------------------------|------------------------|------------------------|-------------------------|-----------------------------|-------------------------|-----------------|
| Jan | 5,635.0                           | 402.30                 | 47.35                  | 154.42                  | 118.20                      | 54.49                   | 6,411.76        |
| Feb | 5,680.7                           | 348.53                 | 40.31                  | 139.48                  | 106.76                      | 49.22                   | 6,365.00        |
| Mar | 5,544.3                           | 286.87                 | 28.28                  | 154.42                  | 118.20                      | 54.49                   | 6,186.56        |
| Apr | 2,269.6                           | 135.35                 | 7.23                   | 149.44                  | 114.39                      | 52.73                   | 2,728.74        |
| May | 264.3                             | 43.24                  | 6.62                   | 154.42                  | 118.20                      | 54.49                   | 635.27          |
| Jun | 0                                 | 3.01                   | 0                      | 149.44                  | 114.39                      | 52.73                   | 319.57          |
| Jul | 0                                 | 0                      | 0                      | 154.42                  | 118.20                      | 54.49                   | 327.11          |
| Aug | 0                                 | 1.50                   | 0                      | 154.42                  | 118.20                      | 54.49                   | 328.61          |
| Sep | 19.8                              | 11.66                  | 0.12                   | 149.44                  | 114.39                      | 52.73                   | 348.14          |
| Oct | 1,809.9                           | 74.82                  | 2.06                   | 154.42                  | 118.20                      | 54.49                   | 2,213.89        |
| Nov | 4,032.2                           | 213.18                 | 17.19                  | 149.44                  | 114.39                      | 52.73                   | 4,579.13        |
| Dec | 5,919.4                           | 354.17                 | 39.43                  | 154.42                  | 118.20                      | 54.49                   | <u>6,640.11</u> |
|     |                                   |                        |                        |                         | TOTAL                       |                         | 37,083.89       |

Table 1.15

**TOTAL NATURAL GAS CONSUMPTION**  
(Btu)

|       | <u>Existing</u>              | <u>Proposed</u>              |
|-------|------------------------------|------------------------------|
| Jan   | 35,492,490,621               | 29,080,700,621               |
| Feb   | 34,416,118,293               | 28,051,118,293               |
| Mar   | 27,863,338,107               | 21,676,778,107               |
| Apr   | 17,223,252,189               | 14,494,512,189               |
| May   | 13,710,496,550               | 13,075,226,550               |
| Jun   | 13,121,400,884               | 12,801,830,884               |
| Jul   | 13,121,400,884               | 12,794,290,884               |
| Aug   | 13,121,400,884               | 12,792,790,884               |
| Sep   | 12,942,492,842               | 12,594,352,842               |
| Oct   | 15,720,697,094               | 13,233,917,094               |
| Nov   | 24,106,219,353               | 19,527,089,353               |
| Dec   | <u>36,935,413,857</u>        | <u>30,295,303,857</u>        |
| TOTAL | 257,774.72 x 10 <sup>6</sup> | 220,417.91 x 10 <sup>6</sup> |

Figure 1.15




Table 1.16

**CHANGE IN COAL CONSUMPTION**  
(10<sup>6</sup> Btu)

|     | <u>ECO</u><br><u>1, 2 &amp; 3</u> | <u>ECO</u><br><u>4</u> | <u>ECO</u><br><u>5</u> | <u>ECO</u><br><u>P1</u> | <u>ECO</u><br><u>P2, P3</u> | <u>ECO</u><br><u>P4</u> | <u>Total</u>     |
|-----|-----------------------------------|------------------------|------------------------|-------------------------|-----------------------------|-------------------------|------------------|
| Jan | 9,264.57                          | 661.42                 | 77.87                  | 253.88                  | 194.34                      | 89.59                   | 10,541.64        |
| Feb | 9,339.66                          | 573.02                 | 66.27                  | 229.31                  | 175.53                      | 80.92                   | 10,464.75        |
| Mar | 9,115.46                          | 471.65                 | 46.50                  | 253.88                  | 194.34                      | 89.59                   | 10,171.46        |
| Apr | 3,731.49                          | 222.53                 | 11.88                  | 245.70                  | 188.06                      | 86.70                   | 4,486.36         |
| May | 434.53                            | 71.09                  | 1.02                   | 253.88                  | 194.34                      | 89.59                   | 1,044.42         |
| Jun | 0                                 | 4.95                   | 0                      | 245.70                  | 188.06                      | 86.70                   | 525.41           |
| Jul | 0                                 | 0                      | 0                      | 253.88                  | 194.34                      | 89.59                   | 537.81           |
| Aug | 0                                 | 2.47                   | 0                      | 253.88                  | 194.34                      | 89.59                   | 540.28           |
| Sep | 32.52                             | 19.16                  | 0.20                   | 245.70                  | 188.06                      | 86.70                   | 572.32           |
| Oct | 2,975.67                          | 123.01                 | 3.38                   | 253.88                  | 194.34                      | 89.59                   | 3,639.87         |
| Nov | 6,629.32                          | 350.49                 | 28.27                  | 245.70                  | 188.06                      | 86.70                   | 7,528.52         |
| Dec | 9,732.10                          | 582.29                 | 64.83                  | 253.88                  | 194.34                      | 89.59                   | <u>10,917.03</u> |
|     |                                   |                        |                        |                         | <b>TOTAL</b>                |                         | <b>60,969.87</b> |

Table 1.17

**TOTAL COAL CONSUMPTION**  
(Btu)

|       | <u>Existing</u>              | <u>Proposed</u>              |
|-------|------------------------------|------------------------------|
| Jan   | 58,022,997,927               | 47,481,357,927               |
| Feb   | 56,253,330,255               | 45,788,580,255               |
| Mar   | 45,479,880,441               | 35,308,420,441               |
| Apr   | 27,986,476,359               | 23,491,106,359               |
| May   | 22,211,141,997               | 21,166,721,997               |
| Jun   | 21,242,607,663               | 20,717,197,663               |
| Jul   | 21,242,607,663               | 20,704,797,663               |
| Aug   | 21,242,607,663               | 20,702,327,663               |
| Sep   | 21,278,479,305               | 20,706,159,305               |
| Oct   | 25,846,135,053               | 22,209,615,053               |
| Nov   | 39,632,802,795               | 32,104,282,795               |
| Dec   | <u>60,725,328,291</u>        | <u>49,808,295,291</u>        |
| TOTAL | 421,164.40 x 10 <sup>6</sup> | 360,188.86 x 10 <sup>6</sup> |

Figure 1.16




Table 1.18

**CHANGE IN ENERGY CONSUMPTION - ALL ECO's**  
(10<sup>6</sup> Btu)

|       | <u>Coal</u>       | <u>Natural Gas</u> | <u>Electricity</u> | <u>Net</u>        |
|-------|-------------------|--------------------|--------------------|-------------------|
| Jan   | -10,541.64        | - 6,411.79         | 1,422.81           | -15,530.62        |
| Feb   | -10,464.75        | - 6,365.00         | 1,348.62           | -15,481.13        |
| Mar   | -10,171.46        | - 6,186.56         | 1,450.05           | -14,907.97        |
| Apr   | - 4,486.36        | - 2,728.74         | 1,093.77           | - 6,121.33        |
| May   | - 1,044.42        | - 635.27           | 719.26             | - 960.43          |
| Jun   | - 525.41          | - 319.57           | - 1.81             | - 846.79          |
| Jul   | - 537.81          | - 327.11           | - 3.01             | - 867.93          |
| Aug   | - 540.28          | - 328.61           | - 2.25             | - 871.14          |
| Sep   | - 572.32          | - 348.14           | 19.84              | - 900.62          |
| Oct   | - 3,639.87        | - 2,213.89         | 489.54             | - 5,364.32        |
| Nov   | - 7,528.52        | - 4,579.13         | 1,409.71           | -10,697.94        |
| Dec   | <u>-10,917.03</u> | <u>- 6,640.11</u>  | <u>1,419.47</u>    | <u>-16,137.67</u> |
| TOTAL | -60,969.87        | -37,083.89         | 9,366.01           | -88,687.79        |



$$\text{Coal} = \frac{60,969.87 \times 10^6 \text{ Btu}}{\text{yr.}} \times \frac{\$2.441}{10^6 \text{ Btu}}$$

$$= \$148,827.45/\text{yr.}$$

$$\text{Natural Gas} = \frac{37,083.89 \times 10^6 \text{ Btu}}{\text{yr.}} \times \frac{\$4.933}{10^6 \text{ Btu}}$$

$$= \$182,934.83/\text{yr.}$$

$$\text{Electricity} = \frac{9,366.01 \times 10^6 \text{ Btu}}{\text{yr.}} \times \frac{\$4.096}{10^6 \text{ Btu}}$$

$$= -\$47,729.19/\text{yr.}$$

$$\begin{array}{l} \text{Total Energy} \\ \text{Cost Savings} \end{array} = \$284,033.09/\text{yr.}$$

The total energy consumption before and after implementation of ECO's is listed in Table 1.19. This is an 8.4 percent decrease in energy consumption at Building 4.

See figure 1.17 for existing versus proposed total energy consumption.

Table 1.19

**TOTAL ENERGY CONSUMPTION**  
(10<sup>6</sup> Btu)

|       | <u>Existing</u>   | <u>Proposed</u>   |
|-------|-------------------|-------------------|
| Jan   | 124,662.75        | 109,132.13        |
| Feb   | 121,816.71        | 106,335.58        |
| Mar   | 104,490.48        | 89,582.51         |
| Apr   | 76,356.99         | 70,235.66         |
| May   | 67,068.91         | 66,108.48         |
| Jun   | 65,511.27         | 64,664.48         |
| Jul   | 65,511.27         | 64,643.34         |
| Aug   | 65,511.27         | 64,640.13         |
| Sep   | 65,368.24         | 64,467.62         |
| Oct   | 72,714.10         | 67,349.88         |
| Nov   | 94,886.29         | 84,188.35         |
| Dec   | <u>128,808.01</u> | <u>112,670.34</u> |
| TOTAL | 1,052,706.29      | 964,018.50        |

Figure 1.17

